



# Monte-Carlo CIPS and CILC assessment to OPR1000 with HIPER16

Sooyoung Lee ([sylee9002@knfc.co.kr](mailto:sylee9002@knfc.co.kr))

KNF 노심설계처 열수력설계부


# Contents

I. Introduction

II. Monte-Carlo CIPS

III. CILC

IV. Summary



# I. Introduction




## CIPS (Crud Induced Power Shift)

- Cause : subcooled nucleate boiling, corrosion products, boron, etc.
- The phenomenon of the axial power distribution bias downward due to the accelerated deposition of boron compounds and crud at the upper part of the cladding
- Assessment : Calculating the amount of the boron deposition in core
- Monte-Carlo simulation : Estimating uncertainties of BOA code input variables
- Threshold
  - Mild CIPS : 230 ~ 450 g (0.5 lbm ~ 1.0 lbm)
  - Severe CIPS : 450 g ~ (1.0 lbm ~ )

# I. Introduction

---

## CILC (Crud Induced Localized Corrosion)

-  The phenomenon of accelerated corrosion of the cladding surface due to the crud deposition
-  Assessment : Crud deposition
  - Tier 1 : 1/4 Assembly scale
  - Tier 2 : Subchannel scale
  - Tier 4 : 20 segmented fuel rod surface scale
-  Threshold
  - Crud thickness  $115.0 \pm 12.5$  microns ( $4.5 \pm 0.5$  mils)

# I. Introduction

## Analyzing Variables

- Number of FAs in Core : 177
- Number of Grid : 13
- Axial length : 165 in

	H	G	F	E	D	C	B	A
8	1 1	2 2	3 3	4 4	5 5	6 6	7 7	8 8
9	16 31	17 32	18 33	19 34	20 35	21 36	22 37	23 38
10	46 61	47 62	48 63	49 64	50 65	51 66	52 67	53 68
11	76 89	77 90	78 91	79 92	80 93	81 94	82 95	83 96
12	102 115	103 116	104 117	105 118	106 119	107 120	108 121	109 122
13	128 139	129 140	130 141	131 142	132 143	133 144	134 145	135 146
14	150 159	151 160	152 161	153 162	154 163	155 164	156 165	157 166
15	168 173	169 174	170 175	171 176	172 177			

## ASSESSMENT Tool

- BOA Code (EPRI, December 2017)
- New fuel location
- AOA interface data
- Lithium/Boron concentration
- RCS Zinc Scenario/Strategy Data

# I. Introduction

---

## Calculation Case

- No reactor trip & No zinc injection (NTNZ)
- Reactor trip & No zinc injection (TNZ)
- Reactor trip & Zinc injection (TZ)
  
- Using ultrasonic fuel cleaning (BOA input variable - FM : 0.4452)


# II. Monte-Carlo CIPS

## Parameter types related to CRUD deposition

- Overall crud source distribution
- In-core crud distribution
- Operation

Descriptions	Dist.	Lower Bound (Fraction of Nominal)	Upper Bound (Fraction of Nominal)	Technical Basis Description
Nickel Alloy Corrosion Rate	Uniform	0.50	1.25	Figure 4-2 in Section 4.1.1 (Ref. [3])
Stainless Steel Corrosion Rate	Uniform	0.50	1.25	Ref. [4]
Crud Mapping Multiplier	Uniform	0.75	1.25	Ref. [5]
Dittus-Boelter Coefficient	Normal	0.70	1.30	Section 2.2.2 (Ref. [3])
Particle Deposition Coefficient	Uniform	0.10	1.00	Section 2.5.3 (Ref. [3])
Particle Release Coefficient(Core)	Uniform	0.33	1.67	Section 2.5.4 (Ref. [3])
Particle Release Coefficient(Other)	Uniform	0.33	1.67	Section 2.5.4 (Ref. [3])
Particle Mass Transfer Coefficient(Core)	Uniform	0.33	1.67	Section 2.5.4 (Ref. [3])
Local Heat Flux	Normal	0.997	1.003	TH Code Sensitivity
Local Pressure	Uniform	0.993	1.007	TH Code Sensitivity
Local Coolant Temperature	Normal	0.997	1.003	TH Code Sensitivity
Local Mass Flux	Normal	0.990	1.010	TH Code Sensitivity

## II. Monte-Carlo CIPS







# II. Monte-Carlo CIPS

## Core Boron Mass

Not applied Monte-Carlo CIPS methodology



The results of Monte-Carlo CIPS





	Severe CIPS	Mild to Moderate CIPS
NTNZ	0 severe CIPS → Satisfied 95/95	0 mild CIPS → mild CIPS occurrence probability under 10 %
TNZ		
TZ		

# III. CILC


## When CILC assessment is required

- In case of maximum crud thickness over 3 mils (75 microns) or 0.75 mils (19 microns) over than previous cycle
- In case that a period of zero mass evaporation rate is greater than 75 % of the total cycle
- In case that utility desire to CILC risk assessment



# III. CILC

Flow chart of CILC assessment




# III. CILC

## CILC Analysis Step 1 : Tier 1 BOA Analysis with Hotspots

### Prepare BOA Code Input

- Set the hotspot location
  - hotspot : Node right under the grid more than 100 in. from the start of the heating length
- Input the hotspot factors
- Applying the same hotspot factor to conservatively evaluate crud deposition for all assemblies




HIPER16 hotspot location

# III. CILC

## CILC Analysis Step 1 : Tier 1 BOA Analysis with Hotspots

### Leading Channel Technique



The period being in top 5 which mass evaporation rate of specific channel > 90 % of total cycle → Increasing the CILC occurrence



Performed CILC Analysis Step 2(Tier 2)

# III. CILC

## CILC Analysis Step 1 : Tier 1 BOA Analysis with Hotspots



# III. CILC

## CILC Analysis Step 2 : BOA Tier 2 Subchannel Analysis

- Using fine mesh modeling
  - Target node selection

1.2	1.1	1.1	1.2	1.2	1.1	1.2	1.2	1.2	1.1	1.1	1.2	1.0	0.5	0.2
1.1	1.1	1.1	0.9	0.9	1.2	1.3	1.3	1.3	1.2	1.1	1.3	1.0	0.5	0.2
1.1	1.1	1.1	0.9	0.9	1.2	1.3	1.3	1.3	1.2	1.2	1.3	1.0	0.5	0.2
1.2	0.9	0.9	1.0	1.1	1.2	1.3	1.3	1.2	1.3	1.3	1.2	0.9	0.4	0.2
1.2	0.9	0.9	1.1	1.2	1.3	1.3	1.3	1.2	1.3	1.2	1.2	0.9	0.4	0.2
1.1	1.2	1.2	1.2	1.3	1.3	1.3	1.3	1.2	1.1	1.1	1.2	0.8		
1.2	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.2	1.1	1.0	1.0	0.7	
1.2	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.2	1.0	0.6	0.3		
1.2	1.2	1.3	1.2	1.2	1.2	1.2	1.3	1.2	1.0	0.8	0.4	0.2		
1.1	1.2	1.2	1.3	1.3	1.1	1.1	1.2	1.0	0.6	0.4				
1.1	1.1	1.2	1.3	1.2	1.1	1.0	1.0	0.8	0.4	0.2				
1.2	1.3	1.3	1.2	1.2	1.2	1.0	0.6	0.4						
1.0	1.0	1.0	0.9	0.9	0.8	0.7	0.3	0.2						
0.5	0.5	0.5	0.4	0.4										
0.2	0.2	0.2	0.2	0.2										

### Target

- Assembly with the highest radial power distribution
- Assemblies with the leading channels of Tier 1

# III. CILC

## CILC Analysis Step 2 : BOA Tier 2 Subchannel Analysis

Using fine mesh modeling

- Target node selection

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
31	32	33	34	35	36	37	38	39	40	41	42	43	44	45
46	47	48	49	50	51	52	53	54	55	56	57	58	59	60
61	62	63	64	65	66	67	68	69	70	71	72	73	74	75
76	77	78	79	80	81	82	83	84	85	86	87	88		
89	90	91	92	93	94	95	96	97	98	99	100	101		
102	103	104	105	106	107	108	109	110	111	112	113	114		
115	116	117	118	119	120	121	122	123	124	125	126	127		
128	129	130	131	132	133	134	135	136	137	138				
139	140	141	142	143	144	145	146	147	148	149				
150	151	152	153	154	155	156	157	158						
159	160	161	162	163	164	165	166	167						
168	169	170	171	172										
173	174	175	176	177										

: Leading Channels(NTNZ, TNZ, TZ)  
 : Leading Channels(TNZ, TZ)  
 : Leading Channels(NTNZ)  
 : Final Selection for Tier 2

### Target


- Assembly with the highest radial power distribution
- Assemblies with the leading channels of Tier 1**

**Selected total 20 nodes  
for CILC Tier 2 Analysis**



# III. CILC

## CILC Analysis Step 2 : BOA Tier 2 Subchannel Analysis

-  Using fine mesh modeling
  - Example of AOA files for fine mesh modeling analysis

Chn No.	Axial node No.	Rod No.	HT surf. No.	Axial elevation	Heat flux	Local press.	Local fluid temp.	Local mass flux	Hydraulic diameter	Heat transfer ratio	Surface area fraction
55	12	1	1	19.3085	15.5865	2270.79	566.26	1.8181	0.6423	1.00	0.004237
55	12	1	2	19.3085	15.5865	2270.78	566.06	2.2289	0.4977	1.00	0.004237
55	12	1	3	19.3085	15.5865	2270.78	565.82	2.2767	0.6423	1.00	0.004237
55	12	1	4	19.3085	15.5865	2270.79	566.05	1.9028	0.8111	1.00	0.004237
55	12	2	1	19.3085	17.2068	2270.78	566.06	2.2289	0.4977	1.00	0.004237
55	12	2	2	19.3085	17.2068	2270.78	566.14	2.3842	0.4977	1.00	0.004237
55	12	2	3	19.3085	17.2068	2270.78	565.86	2.4311	0.6423	1.00	0.004237
55	12	2	4	19.3085	17.2068	2270.78	565.82	2.2767	0.6423	1.00	0.004237


# III. CILC

## CILC Analysis Step 2 : BOA Tier 2 Subchannel Analysis

Using fine mesh modeling


- Example of AOA files for fine mesh modeling analysis

Chn No.	Axial node No.	Rod No.	HT surf. No.	Axial elevation	Heat flux	Local press.	Local fluid temp.	Local mass flux	Hydraulic diameter	Heat transfer ratio	Surface area fraction
55	12	1	1	19.3085	15.5865	2270.79	566.26	1.8181	0.6423	1.00	0.004237
55	12	1	2	19.3085	15.5865	2270.78	566.06	2.2289	0.4977	1.00	0.004237
55	12	1	3	19.3085	15.5865	2270.78	565.82	2.2767	0.6423	1.00	0.004237
55	12	1	4	19.3085	15.5865	2270.79	566.05	1.9028	0.8111	1.00	0.004237
55	12	2	1	19.3085	17.2068	2270.78	566.06	2.2289	0.4977	1.00	0.004237
55	12	2	2	19.3085	17.2068	2270.78	566.14	2.3842	0.4977	1.00	0.004237
55	12	2	3	19.3085	17.2068	2270.78	565.86	2.4311	0.6423	1.00	0.004237
55	12	2	4	19.3085	17.2068	2270.78	565.82	2.2767	0.6423	1.00	0.004237



# III. CILC

## CILC Analysis Step 2 : BOA Tier 2 Subchannel Analysis



Crud thickness threshold  
 $115.0 \pm 12.5$  microns ( $4.5 \pm 0.5$  mils)  
➡ Satisfied




Crud thickness > 5 mils  
➡ Need to perform Tier 4

# III. CILC

## CILC Analysis Step 3 : BOA Tier 4 Analysis

### CFD Analysis

using 20 azimuthal CFD determined heat transfer coefficients with the subchannel




# III. CILC


## CILC Analysis Step 3 : BOA Tier 4 Analysis

### CFD Analysis

Program : Ansys Fluent (Version 2020 R2)



Mesh of mixing vanes



Near wall treatment

# III. CILC

## CILC Analysis Step 3 : BOA Tier 4 Analysis

### Heat transfer rate

$$HTR_{i,j,k,l} = \frac{HTC_{CFD_{i,j,k,l}}}{HTC_{i,j,k,l}} = \frac{\frac{q'_{i,j,k,l}}{T_{CFD_{i,j,k,l}} - T_{b_{i,j,k,l}}}}{HTC_{i,j,k,l}}$$

where,  $HTR$  : Heat transfer coefficient ratio

$HTC$  : Heat transfer coefficient [Btu/hr-ft<sup>2</sup>-°F]

$I$  : 1/4 assembly ID

$j$  : axial node ID

$k$  : rod ID

$l$  : surface ID

$q''$  : heat flux [Btu/hr-ft<sup>2</sup>]


$T_{CFD}$  : surface temperature calculated by CFD [°F]

$T_b$  : bulk temperature calculated by subchannel analysis code [°F]

# III. CILC

## CILC Analysis Step 3 : BOA Tier 4 Analysis

### Heat transfer rate example





- Calculated all rods in 8.5x8.5 model
- Difficulty in deriving a representative distribution because of flow mixing by mixing vane
- For each rod where large amount of crud are expected to be deposited, the appropriate HTR should be applied.



# III. CILC

## CILC Analysis Step 3 : BOA Tier 4 Analysis











# IV. Summary

---

## Calculation Cases

-  No reactor trip & No zinc injection (NTNZ)
-  Reactor trip & No zinc injection (TNZ)
-  Reactor trip & Zinc injection (TZ)



## Monte-Carlo CIPS

-  Maximum core boron mass not exceeding 0.5 lbm
-  Maximum crud thickness not exceeding 3 mils
-  Period of zero mass evaporation rate are less than 75 % of the total cycle




# IV. Summary

---

## CILC Tier 1 and 2

-  Tier 1 : The period being in top 5 which mass evaporation rate of specific channel > 90 % of total cycle
-  Tier 2 : Maximum crud thickness not exceeding 5 mils

## CILC Tier 4

-  CFD Analysis for HIPER16 8.5×8.5 model
-  Performed the Tier 4 assessment about NTNZ case
-  **Next Step**

**CFD Analysis about full scale model and calculating all rods heat transfer coefficient**

**감사합니다**

