## Structural analysis of the moderator vessel and vacuum tube in CNS

,

,

150

Service level A

Service level B,C,D

cover ASME SC-1

## Abstract

The purpose of the study is to carry out the structural analysis of the moderator vessel and vacuum tube to be installed in HANARO. The stress calculation was performed to verify the design of the moderator vessel and vacuum tube under Service level A condition. The loads taken into account in this analysis are pressure during normal operation, seismic events and thermal expansion. The detail analysis will be performed after the design loads of Service level B,C,D is given. For the detail analysis, the loads such as failure of the moderator vessel and overpressure in cover gas should be considered by the accident analysis. The calculated stresses satisfied the ASME SC-1 component design and analysis rules. Also,through the buckling analysis, the structural integrity was verified in the vacuum tube such a long cylinder type.

1.

 (Cold Neutron Source)
 ブ

 Hawell
 BEPO 1957

 30
 ,
 ,

 ブト
 ブト
 .

 1990
 .

JRR-3 NIST NBSR 1991 in-pile assembly (Horizontal Type) • (Vertical Type) 가 가 . . 가 가 open-pool , 1 . 가 가 가 . . [1]. Service level B,C,D , cover 2. 가 가 . 가 2 . 3 Inner Cylinder Outer Cylinder Inner Cylinder . 10m • 가 . 가 가 •

 7ł
 1.5atm

 2mm
 134mm
 7ł
 216mm

 1
 .
 2atm

.

3.2m .

4 . 159mm 가 2 5mm [2]. 3. 3.1 (1) 가 ANSYS code 2 6 180° 5 AL6061-T6 AL6061-1.95atm T6 3 . 가 1.3 4 . 1.0 SSE event . ground ZPA 1.33 8 plane82 . 3513 924 . x,y х [3]. (2) 2 . 7 . 가 8 142 . 1323 . ASME AL6061-T6  $S_m$  93MPa . 1 16.7 MPa 139.5MPa 1.5S<sub>m</sub> . . 142 2 21.4MPa . 가 . ORNL HEIR 40K CNS 20K 가 20MPa . 2  $1.5S_{\rm m}$ 41.4MPa 1.5S<sub>m</sub> . 9

.

3 6 [4]. 3.2

(1)

Zircaloy-4가 5 [5]. ANSYS 2 10 11 3 가 ASME 가 가 . 2 8 PLANE 82가 2549 9864 가 x,y . Х • 4 3 Shell 63 1.4m CNS Х .

(2)

2 ASME 가 Design by analysis 가 12 13 4287 166 . . 166 4.72 MPa zircaloy-4 S<sub>m</sub>  $1.5S_{m}$ 100MPa 9.24 MPa 2 . 가 .

ASME 7 : 7 14 3 . . . P<sub>cr</sub>

7ト . . 15 . . 0.078m 7ト . 2.87 MPa 0.26 MPa

## 10.9 buckling load factor

[6].

1

1. Containment strength report, KAERI/PNPI, HCNS-CD5506403.000AR, 1997

2. 1 ,"Preliminary structural analysis of moderator vessel and vaccum tube for the HANARO", LMRMEDD/CNS-01/2004, 2004.

3. High flux isotope reactor cold neutron source reference design concept, ORNL/TM-13498, May 1998.

4. Tai-Cheng Guung, Wen Fa Tsai, Weng-Sheng Koo and Jong Sheng Chen,"MCNP simulation of TRR-II cold neutron source design", Physica B 311, pp158-163, 2002.

5. Erwin Gutsmie and Anton Scheuer," Use of zircaloy 4 material for the pressure vessel of hot and cold neutron sources and beam tubes for research reactors, Physica B 311, pp 182-190, 2002.

6. Y. Ogata, Y. Kiyanagi, N. Kosugi, H. Iwasa, M. Furusaka and N. Watanabe,"Intensity enhancement of cold neutron from a coupled liquid-hydrogen moderator for pulsed cold neutron sources", Nuclear Instruments and Methods in Physics research A 432, pp415-421, 1999.

Content	Dimension(mm)
Moderator vessel outer diameter	134
Moderator vessel length	216
Moderator vessel thickness	2

2	
Content	Dimension(mm)
Vaccum tube outer diameter	159
Vaccum tube length	3214
Vaccum tube thickness	5

3	AL6061-T6	
Content		Value
Young's modulus		77.7 GPa
Poisson ratio		0.33
Coefficient of thermal expans	ion	14.1x10 <sup>-6</sup> / <sup>o</sup> K

4	Zircaloy-4	
Content		Value
Young's modulus		100 GPa
Poisson ratio		0.32
Coefficient of thermal exp	ansion	5.89x10 <sup>-6</sup> / <sup>o</sup> K

5

Load	Ground ZPA(g)	Equivalent Static Inertial Load(g)		
Event		Horizontal	Vertical	
OBE	0.1	0.1	0.0667	
SSE	0.2	0.2	0.133	

6

Stress	Linearized stress	Calculated	Allowable	Remarks
Categorization	intensity	stress intensity	limits(1.5S <sub>m</sub> )	
Primary stress	Local membrane	16.7 MPa	139.5 MPa	* The bending stresses
				due to the discontinuity
Secondary	Bending +	41.4 MPa	139.5 MPa	are included in the
stress	Thermal stress			secondary stress.

Design stress intensity(S<sub>m</sub>): 93 MPa

7

,				
Stress	Linearized stress	Calculated	Allowable	Remarks
Categorization	intensity	stress intensity	limits(1.5S <sub>m</sub> )	
Primary stress	Local membrane	4.72 MPa	150 MPa	* The bending stresses
				due to the discontinuity
Secondary	Bending +	39 MPa	150 MPa	are included in the
stress	Thermal stress			secondary stress.

Design stress intensity(S<sub>m</sub>): 100 MPa







2 Moderator vessel outer cylinder

2



3 Moderator vessel outer cylinder inner cylinder 3







