

2003

ACP 가
**Radiation Dose Assessment of
ACP Hotcell in Accident**

, , , , ,

150

(ACP: Advanced spent fuel Conditioning Process)

가 . 가 가 가 가 가 가

Abstract

The Advanced spent fuel Conditioning Process(ACP) is under development for the effective management of spent fuel which had been generated in nuclear plants. The ACP needs a hot cell where most operations will be performed. To give priority to the environment safety, radiation doses evaluations for the radioactive nuclides in accident cases were preliminarily performed with the meteorological data around facility site. Fire accident prevails over several accidents. Internal Dose & External Dose evaluation according to short dispersion data for that case show a safe margin for regulation limits and SAR limit of IMEF where this facility will be constructed.

1.

1/4

[1]

$\alpha - \gamma$

가

가

가

.
가

가

.

2. 가

2.1.

가

,

,

,

.

2.2.

3가

가

.

가

가

가

.

가

가

가

.

.

.

가

Slitting Machine

Cutter가

가

가

3가

2.3.

PWR

ANS Standard

$$\frac{10 \text{ PWR}(4 \text{ w/o})}{1.4 \text{ kW/MTU}} \times 0.1 \text{ MTU} = 0.14 \text{ kW}$$

HEPA

•

0.5 % χ/Q χ/Q 16 χ/Q
 χ/Q 16 χ/Q
Q 5% χ/Q 16 가 5.0 %
Fumigation

$$\frac{\chi}{Q} = \frac{1}{(2\pi)^{1/2} U_{h_e} \sigma_y h_e}, \quad h_e$$

U_{h_e} : 가 h_e (m/sec)

σ_y : (m)

Fumigation χ/Q Nonfumigation χ/Q χ/Q
30 χ/Q 2 Fumigation χ/Q
 χ/Q 5% χ/Q
. 2 1.111
2

가 1.145 PAVAN

2002 1 χ/Q

Nonfumigation
((χ/Q)99.5), Fumigation ((χ/Q)f)
((χ/Q)95) 3

3 Nonfumigation F
umigation

0 2
W 400m 1.38×10^{-2}

4.

()

가

가

(ICRP 60)

US NRC Regulatory Guide 1.4 $3.47 \times 10^{-4} \text{ m}^3/\text{sec}$

가

4 .

$$D_{th} = 10^{12} \times \chi/Q \times B \times \sum_i (DCF_{thi} \times Q_i)$$

,
 D_{th} : 가 (mSv)
 10^{12} : (pCi/Ci)
 χ/Q : (sec/m³)
 B : (m³/sec)
 DCF_{thi} : i 가
 (mSv/pCi-inhaled)
 Q_i : (Ci)

가 . ,
 (Semi- infinite Hemi-spherical Cloud) ,
 가 .
 Eckerman

5

$$D_{wb} = 10^{12} \times \chi/Q \times \sum_i (DCF_{wbi} \times Q_i)$$

,
 D_{wb} : (mSv)
 10^{12} : (pCi/Ci)
 χ/Q : (sec/m³)
 DCF_{wbi} : i (mSv - m³/pCi - sec)
 Q_i : (Ci)

5. 가

6 .
 Kr-85가
 가
 H-3 Ru-106 가
 가 I-129 . 6

1.

()	(kW/MT U) PWR (4w/o)
0.0	2,336
0.5	20.7
1.0	11.9
2.0	6.2
3.0	3.9
4.0	2.8
5.0	2.2
6.0	1.9
8.0	1.6
10.0	1.4
15.0	1.2
20.0	1.1

2.

	(Ci)	HEPA	(Ci)
		DF = 1000	
H - 3	5.76E +01	1.000E +00	5.76E +01
C - 14	1.74E - 03	1.000E +00	1.74E - 03
Se - 79	1.74E - 03	3.000E - 04	5.23E - 07
Kr - 85	6.21E +02	1.000E +00	6.21E +02
Mo - 93	2.71E - 06	3.000E - 04	8.12E - 10
Tc - 99	1.65E +00	3.000E - 04	4.95E - 04
Ru - 103	2.26E - 23	3.000E - 04	6.79E - 27
Ru - 106	7.74E +01	3.000E - 04	2.32E - 02
Cd - 113M	4.91E +00	3.000E - 04	1.47E - 03
Cd - 115M	5.89E - 23	3.000E - 04	1.77E - 26
Te - 125M	1.23E +00	3.000E - 04	3.69E - 04
Te - 127	5.34E - 09	3.000E - 04	1.60E - 12
Te - 127M	5.45E - 09	3.000E - 04	1.64E - 12
Te - 129	2.74E - 27	3.000E - 04	8.21E - 31
Te - 129M	4.20E - 31	3.000E - 04	1.26E - 34
Sb - 124	1.41E - 16	3.000E - 04	4.22E - 20
Sb - 125	1.50E +02	3.000E - 04	4.50E - 02
Sb - 126	1.40E - 02	3.000E - 04	4.21E - 06
Sb - 126M	1.00E - 01	3.000E - 04	3.01E - 05
I - 129	4.10E - 03	1.000E +00	4.10E - 03
Cs - 134	2.12E +01	3.000E - 04	6.36E - 03
Cs - 135	9.34E - 04	3.000E - 04	2.80E - 07
Cs - 137	2.49E +02	3.000E - 04	7.46E - 02
Total	1.18E +03		6.79E +02

3. 2 (: sec/m³)

	(m)	(χ/Q) _{99.5}	(χ/Q) _f	(χ/Q) ₉₅
S	700	7.56×10^{-3}	5.60×10^{-4}	5.01×10^{-3}
SSW	800	3.17×10^{-4}	1.83×10^{-4}	
SW	1000	1.03×10^{-3}	2.70×10^{-4}	
WSW	700	6.30×10^{-3}	5.60×10^{-4}	
W	400	1.38×10^{-2}	1.43×10^{-3}	
WNW	400	8.67×10^{-3}	1.43×10^{-3}	
NW	700	2.27×10^{-3}	5.60×10^{-4}	
NNW	600	4.56×10^{-3}	7.24×10^{-4}	
N	700	5.47×10^{-3}	5.60×10^{-4}	
NNE	700	6.34×10^{-3}	5.60×10^{-4}	
NE	900	2.78×10^{-3}	3.68×10^{-4}	
ENE	800	2.92×10^{-4}	1.74×10^{-4}	
E	300	8.59×10^{-5}	2.37×10^{-4}	
ESE	300	6.13×10^{-5}	2.24×10^{-4}	
SE	300	7.84×10^{-5}	2.30×10^{-4}	
SSE	800	1.53×10^{-3}	3.88×10^{-4}	

4.

	(Ci)	(mSv/pCi-inhaled)	가 (mSv/pCi-inhaled)	(mSv)	가 (mSv)
H - 3	5.76E +01	6.660E - 10	6.660E - 10	1.84E - 01	1.84E - 01
C - 14	1.74E - 03	2.290E - 10	2.290E - 10	1.90E - 06	1.90E - 06
Se - 79	5.23E - 07	4.070E - 08	1.410E - 08	1.02E - 07	3.53E - 08
Mo - 93	8.12E - 10	3.170E - 10		1.23E - 12	
Tc - 99	4.95E - 04	1.480E - 07	8.880E - 09	3.51E - 04	2.11E - 05
Ru - 103	6.79E - 27	8.880E - 08	7.030E - 09	2.89E - 27	2.29E - 28
Ru - 106	2.32E - 02	1.040E - 06	9.990E - 08	1.16E - 01	1.11E - 02
Cd - 113M	1.47E - 03	4.970E - 08		3.50E - 04	
Cd - 115M	1.77E - 26	7.950E - 09		6.72E - 28	
Te - 125M	3.69E - 04	5.840E - 10	1.310E - 09	1.03E - 06	2.32E - 06
Te - 127	1.60E - 12	3.870E - 13	1.320E - 12	2.97E - 18	1.01E - 17
Te - 127M	1.64E - 12	2.740E - 07	3.180E - 08	2.15E - 12	2.49E - 13
Te - 129	8.21E - 31	1.550E - 14	1.870E - 14	6.10E - 38	7.35E - 38
Te - 129M	1.26E - 34	2.440E - 07	3.700E - 08	1.47E - 34	2.23E - 35
Sb - 124	4.22E - 20	2.370E - 07	2.410E - 08	4.78E - 20	4.87E - 21
Sb - 125	4.50E - 02	1.780E - 07	2.040E - 08	3.83E - 02	4.39E - 03
Sb - 126	4.21E - 06	1.040E - 07	1.330E - 08	2.10E - 06	2.68E - 07
I - 129	4.10E - 03	3.550E - 06	7.030E - 05	6.97E - 02	1.38E +00
Cs - 134	6.36E - 03	2.440E - 07	2.330E - 07	7.43E - 03	7.10E - 03
Cs - 135	2.80E - 07	5.990E - 08		8.04E - 08	
Cs - 137	7.46E - 02	1.700E - 07	1.630E - 07	6.07E - 02	5.82E - 02
Total	5.77E +01			4.76E - 01	1.65E +00

5.

	(Ci)	(mSv/sec PER pCi/ m ³)	(mSv)
Kr - 85	6.21E +02	4.403E - 15	3.77E - 02
T o t a l	6.21E +02		3.77E - 02

6.

가

		(Sv)		
		()	()	가 ()
	[4]	0.25	0.25	3.0
	IMEF	2.5×10^{-3}	2.5×10^{-3}	3.0×10^{-2}
가		3.77×10^{-5}	4.76×10^{-4}	1.65×10^{-3}

1. , ,
KAERI/TR- 2092/ 2002, 2002
2. , 가(2002), 2002
3. US NRC Regulatory Guide 1.145 "Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plant" Rev.1, 1982
4. , 2002- 23 , “ ”