

# Development and Seismic Evaluation of the Seismic Monitoring Analysis System for HANARO

150

가

(SMAS)

가

(SAT)

가

가

## Abstract

Since the start of operation, the seismic monitoring system has been utilized for monitoring an earthquake at the HANARO site. The existing seismic monitoring system consists of field sensors and monitoring panel. The analog-type monitoring system with magnetic tape recorder is out-of-date model. In addition, the disadvantage of the existing system is that it does not include signal-analyzing equipment. Therefore, we have improved the analog seismic monitoring system except the field sensors into a new digital seismic monitoring analysis system(SMAS) that can monitor and analyze earthquake signals. To achieve this objective for HANARO, the digital type hardware of the SMAS has been developed. The seismic monitoring and analysis programs that can provide rapid and precise information for an earthquake were developed. After the installation of the SMAS, we carried out the site acceptance test (SAT) to confirm the functional capability of the newly developed system. The results of the SAT satisfy the requirements of the fabrication technical specifications. In addition, the seismic characteristics and structural integrity of the SMAS were evaluated. The results show that the cabinet of SMAS can withstand the effects of seismic loads and remain functional. This new SMAS is operating in the HANARO instrument room to acquire and analyze the signal of an earthquake.

1.

(panel) 가 3 , 1 가  
 1 , 가  
 ,  
 가 가 .  
 가  
 ( ) 1 .


(HANARO Seismic Monitoring Analysis System)

[1~5] ( 1 ,  
 1 ) [6] ,  
 , [7].  
 ,  
 [8].  
 가  
 [9].


2.

1 . 1 (a)  
 ,  
 (panel) .  
 ,  
 (seismic trigger) 1 , (seismic switch) 1 가 3  
 . (base slab) ,  
 OBE(Operating Basis Earthquake) 1/10 ,  
 (WN-34)가 ,  
 (free field), (crane support) 가  
 가 .

OBE 가 ,  
(WN-33)가 , 3 가 가



(a)



(b)

1

1(b)  
(MCU), (ANN), (ICU), (IPC)  
(LCD)  
(MCU) VME bus  
(MCM),  
(event) (DAM),  
/ (DIM/DOM),  
(AOM),  
(FMM)  
(IPC)  
(ANN)  
(LED)  
(buzzer)

FTM, (ICU) 가 (DAM)  
 (DIM) STM (DIM) TTM,  
 (PSM) (UPS),  
 PSM #1 PSM #3, PSM #2  
 PSM #4

(MCM) (IPC) (LCD)

3.

3.1

(real-time)

(GUI)

가

2




2

4 , 가


3 3 (a)

가

3 (b)




(a)



(b)



(c)



(d)

3

3 (c)

(MCU)

( 3 (d)).


### 3.2

(Operating Basis Earthquake)

가 , 가  
가 ,

가 ,

4



4

5


가

(time domain)


가

5 (b)

가



(a)




(b)

5


6

FFT (Filtering) , 6 (a) OBE SSE

6 (b) FFT (Filtering) FFT



(a)



(b) FFT

6

Reg. Guide 1.166[3]

(Frequency Response Spectrum)

(Cumulative Absolute


Velocity)가 OBE

7


Absolute Velocity)

(Cumulative

가



(a)



(b)

7



5.1

가

[6] 가

1 가

가

RRS(Required Response Spectra) / 1 TRS(Test Response Spectra) RRS

1 1 , OBE

RRS / 1 RRS TRS

, / 1 OBE

SSE SSE RRS가

/ 1 RRS TRS , RRS

/ 1 RRS TRS 5 Hz ~ 8 Hz

1 , 1

[10]

1 가 13.25 Hz 33.75 Hz , 1 /

1 SSE RRS 5 Hz ~ 8 Hz

1

/ 1

1 ( : Hz)

	Side-to-Side	Front-to-Back		
1	11.00	32.75		2350mm
1	13.75	36.00		2350mm
	13.25	33.75		2000mm

5.2


가

(base plate) 8 10mm

600mm 150mm , 4 5mm  
 60mm  
 (600\*2000\*800) (W\*H\*D),

3  
 Reg. Guide 1.61[11] OBE 2%, SSE  
 4% 가

1.5  
 B C  
 B가 B 3  
 12.7 MPa  
 209 MPa



8

5.3

가

( ) (embedded plate)

가 Base Plate(22t) 5.2

, 8

HILTI HSL M16/25, ISO 8.8 GRADE STEEL 8 가  
 148 mm, 125 mm 가

HILTI [12]

20.2 kN , 23.2 kN B ( ) 가 가 가 13.5 kN, 4.7 kN ,

6.

가

, 가, 가

[1] “ ,” 1 3 , , KAERI/TR-701/96, , 1996.

[2] U.S. Atomic Energy Commission, “Nuclear Power Plant Instrumentation for Earthquakes (Reg. Guide 1.12),” Rev. 2, 1997.3.

[3] U.S. Atomic Energy Commission, “Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Post Earthquake Actions (Reg. Guide 1.166),” 1997.3.

[4] U.S. Atomic Energy Commission, “Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants (Reg. Guide 1.100),” 1988.6.

[5] IEEE Std 344-1987, “IEEE Recommended Practice for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations” 1987.

[6] SAEHAN Engineering & Qualification Co., Ltd., “Dynamic Qualification for Seismic Monitoring System Manufactured by WOORIGISOOL Co., Ltd. for KORI NPP, Unit 2 and YONGGWANG NPP, Units 1&2,” 2000. 3.

[7] , “ ,” KAERI/TR-1961/2001, , 2001.

- [8] , , “ ,” , KAERI/TR-2568/2003, , 2003.
- [9] , “ 가,” , KAERI/TR-2524/2003, , 2003.
- [10] D. J. Ewins, *Modal Testing: Theory and Practice*, Research Studies Press, Letchworth, England, 1984.
- [11] U.S. Atomic Energy Commission, “Damping Values for seismic Design of Nuclear Power Plants (Reg. Guide 1.16),” 1973. 10.
- [12] HILTI Inc., *Fastening Technology Manual*, pp. 33-35, 2001.