

/ 가

Review of Cause-Based Decision Tree Approach for the  
Development of Domestic Standard Human Reliability Analysis Procedure  
in Low Power/Shutdown Operation Probabilistic Safety Assessment

/ 가

가,

THERP

THERP 가

/ 가

**Abstract**

We review the cause-based decision tree (CBDT) approach to decide whether we incorporate it or not for the development of domestic standard human reliability analysis (HRA) procedure in low power/shutdown operation probabilistic safety assessment (PSA). In this paper, we introduce the cause based decision tree approach, quantify human errors using it, and identify merits and demerits of it in comparison with previously used THERP. The review results show that it is difficult to incorporate the CBDT method for the development of domestic standard HRA procedure in low power/shutdown PSA because the CBDT method need for the subjective judgment of HRA analyst like as THERP. However, it is expected that the incorporation of the CBDT method into the development of domestic standard HRA procedure only for the comparison of quantitative HRA results will relieve the burden of development of detailed HRA procedure and will help maintain consistent quantitative HRA results.

1.

가(probabilistic safety assessment: PSA)

가 가

[1].

(Human Reliability Analysis: HRA)

/

PSA

HRA

PSA

HRA

HRA

HRA

HRA

HRA

HRA

[ 2,3 ].

PSA

ASEP(accident sequence

evaluation procedure) HRA [ 4 ], THERP(technique for human error rate prediction) [ 5 ],

HCR/ORE(human cognitive reliability/operator reliability experiment) [ 6 ], CBDT(cause based decision

tree) [ 6 ]

HRA

HRA

ASEP

THERP

HRA

(risk-informed)

가

가

PSA

PSA

ASME PRA Standard[ 7 ] NEI PRA Peer Review Guideline[ 8 ]

(ANS)

/

PSA

PRA standard

[9]

ASEP, THERP, HCR

/

HRA

CBDT

/

PSA

가

CBDT

/

PSA

HRA

THERP

ASEP

, HRA

ASEP

THERP

/

HRA

[ 10,

11 ].

PSA

HRA

[ 10 ]

ASEP

,

THERP

5&6 PSA

HRA

[ 11 ] THERP

5&6

PSA

HRA

THERP

:

●

■ THERP

(cognitive)

■

가

●

가

:

PSA

가

/ PSA HRA CBDT  
CBDT

가, / PSA THERP  
. 2 CBDT ,

HRA HRA . 3 5&6 / PSA  
THERP HRA CBDT  
4 .

## 2. CBDT

CBDT [ 6 ] 5&6 / PSA  
HRA 가 .

### 2.1

CBDT HCR Parry 가 .  
PSA

HCR(human cognitive reliability )  
가 .

(time response curve:

TRC) (extrapolation) HCR .  
CBDT . HCR THERP  
, CBDT  
가 :

$$P = P_c + P_E - P_c * P_E \dots \dots \dots ( 1 )$$

P:

P<sub>c</sub>: - , ,

P<sub>E</sub>:

P<sub>c</sub> 8가 가 . 1 8가  
. 1 1 (P<sub>c</sub><sup>a</sup>)

가 .

가 .

가

가 가

가 가 :

$$P_c = \sum_{i=1,2} \sum_j P_{ij} P_{nr}^{ij} \dots \dots \dots (2)$$

$P_{ij}$ :            i            j


$P_{nr}$ :            i            j

가             $P_c$

**1. CBDT**

1:		2:	
$P_c^a$	가            가	$P_c^e$	
$P_c^b$	가            가	$P_c^f$	
$P_c^c$	가            가 ,	$P_c^g$	
$P_c^d$	가            가	$P_c^h$	

Ind. Avail In CR	CR Ind. Accurate	Warn/Alt. In Proc.	Training On Ind.	$P_c^a$
---------------------	---------------------	-----------------------	---------------------	---------



1.            a            ,

a:

- 1) indication avail in CR:            가            가            ?
- 2) CR indication accurate:            가            ?
- 3) Warning/alternate in procedure:            가            ?
- 4) Training on indicators:            ?

CBDT

:

- 1)
- 2)
- 3)
- 4)
- 5)

**2.2. CBDT**

가  
 2 가 3  
 가 가 2 : POS 3(  
 )  
 10 CBDT  
 15

**2. CBDT** 가

WORKSHEET FOR CALCULATION OF P <sub>C</sub>				
Scenario:	SCS fail during shutdown cooling operation			
HI:	Restart Standby SCS pumps			
Cue(s):	Alarm for SYSTEM TRN A/C, B/D INOP, Alarm for LPSI PUMP 01A/01B DISCH FLOW LO or LO-LO			
Duration of time window available for action (T <sub>w</sub> ): 10min.			600 seconds	
Approximate start time for T <sub>w</sub> :		t=0 (time at which IE occurs)		
Procedure and step governing HI:		Ulchin AOM-33,		
<b>A. Initial Estimate of P<sub>C</sub></b>				
	P <sub>C</sub> Failure Mechanism	Branch	HEP	Reduce T <sub>w</sub> by
P <sub>C</sub> <sup>a</sup>	Availability of information	A	Neg.	- min.
P <sub>C</sub> <sup>b</sup>	Failure of attention	A	Neg.	N/A
P <sub>C</sub> <sup>c</sup>	Misread/miscommunicate data	B	0.003	~ min.
P <sub>C</sub> <sup>d</sup>	Information misleading	A	Neg.	N/A
P <sub>C</sub> <sup>e</sup>	Skip a step in procedure	D	0.01	~min.
P <sub>C</sub> <sup>f</sup>	Misinterpret instruction	A	Neg.	N/A
P <sub>C</sub> <sup>g</sup>	Misinterpret decision logic	L	Neg..	N/A
P <sub>C</sub> <sup>h</sup>	Deliberate violation	A	Neg.	N/A
<b>Initial P<sub>C</sub> = 1.3E-2, Effective T<sub>w</sub> =5 min.</b>			1.3E-2	5min.
Check here if recovery credit claimed ( )				
Notes: no recovery factor due to short available time				

5&6 / 가  
 CBDT 가 가 3 3 1  
 2 2 1  
 4가 /  
 가  
 1 2, 3 4



5&6 / PSA THERP . THERP

가 :

- = ( ) X (factors)
- = Σ [ X ]

5&6 PSA HRA

가 , (hesitancy) , /

가 ,

가 CBDT THERP

4 . CBDT

THERP

가 THERP

- ASME PRA standard HRA (decision tree)

ASME PRA standard

- , 가  
가

- THERP 가 가

( , 가)

가

CBDT / PSA HRA ASEP THERP

가 ( , , )

) THERP 가

/ PSA HRA

. THERP ASEP

HRA

HRA

. CBDT





가, THERP  
 , CBDT /  
 PSA HRA ASEP THERP 가  
 ( , )  
 THERP 가 HRA / PSA  
 HRA HRA  
 HRA  
 HRA

- [ 1 ] E.M. Dougherty & J.R. Fragola, "Human Reliability Analysis: A System Engineering Approach With Nuclear Power Plant Applications", SAIC, John Wiley & Sons, 1988
- [ 2 ] , " PSA", 2002. KNS
- [ 3 ]. EPRI, "HRA Calculator – seminar material", 2001
- [ 4 ] A.D.Swain, "Accident Sequence Evaluation Program Human Reliability Analysis Procedure", NUREG/CR-4772, S.N.L, Feb. 1987
- [ 5 ] A.D.Swain and H.E.Guttman, "Handbook of Human Reliability Analysis with Emphasis on Nuclear Power Plant Applications", NUREG/CR-1278, S.N.L, Aug. 1983
- [ 6 ] J.G.W. Parry et al., "An Approach to the Analysis of Operator Actions in Probabilistic Risk Assessment", EPRI/TR-100259, 1992
- [ 7 ]. ASME, "Standard for PRA for NPP Applications", Rev. 14A, 2001
- [ 8 ]. NEI, "PRA Peer Review Process Guidance", NEI-00-02, Rev. A3, 2000
- [ 9 ] ANS, "Low-Power Shutdown PRA methodology standard", Draft, 2002
- [ 10 ] , " PSA",
- [ 11 ] , " 5&6 / PSA"