


DB

Component Reliability Analysis for Development of Component Reliability DB of Korean Standard NPPs


가
150, sychoi@kaeri.re.kr



Abstract

The reliability data of Korean NPP that reflects the plant specific characteristics is necessary for PSA and Risk Informed Application. We have performed a project to develop the component reliability DB and calculate the component reliability such as failure rate and unavailability. We have collected the component operation data and failure/repair data of Korean standard NPPs. We have analyzed failure data by developing a data analysis method which incorporates the domestic data situation. And then we have compared the reliability results with the generic data for the foreign NPPs.

1.



2. DB

가 가 가 가

가


DB , 가

PSA

PSA

RIR&A PSR (Periodic Safety Review)

2 1 DB




2.

1.

	/ 가
	.

	가 .
	, ,
OOS	가 out of service
	/ 가
OOS	OOS 가



3. DB

3 DB

가 2 DB (relational) DB

[2]

2. DB

		, , ,
		, ,

가 가 . 가 ,
(OOS: Out Of Service)
가
(OOS) 가 가
가 가 ,
가 가
OOS .

- : ,
- (1): (spurious operation)

= /
- (2): 가
= /
- : 10 가 가 가
가, 12 가 가 가
= /

- : 가
가
= (OOS) / ()

3. 가

	Fails to Run Trip	2	
	Fails to Start	1	
, circui breaker	Fails to Operate	1	. 1

	Spurious Operation, Failure , Plugging, Leakage	1	
--	--	---	--

3

가

[1]

4



OOS

OOS

가

가


가

가

OOS

6

OOS



4. OOS


4 OOS

가



, OOS

가 2

가



5. OOS



가

가

가

(, ,)

가

(2 3)

가 가

가 가

4

4

4

[1]

4.

/ /		
	/	
Plant	O/H 가 ()	
	가 2 가	

4.

3

. 3,4 1998 , 3,4
2000

3,4 5,6 PSA (Probabilistic Safety Assessment,
가) , BOP

, 24 . 33 , 22000

, 6300

5.

			()	()	
3	1995-04-01	1998-12-31	1371	1176	0.858
4	1996-01-01	1998-12-31	1096	980	0.895
3	1998-08-11	2000-12-31	874	765	0.875
4	2000-01-01	2000-12-31	366	302	0.825

6.

Pump	350	2253	Heat Exchanger	70	44
Pump -AFW Diesel Pump	4	52	Heater	58	30
Pump -AFW Motor Pump	8	57	Heater -Electric	34	20
Pump -AFW Turbine Pump	4	2	Heater -Steam	24	10
Pump -CCW Pump	20	85	Refrigerator	4	16
Pump -Charging Pump	14	356	Tank	179	90
Pump -Circulating Water Pump	24	361	Check Valve	1488	64
Pump -CS Pump	8	25	Deluge Valve	101	30
Pump -ECW Pump	16	46	Manual Valve	7605	308
Pump -ESW Pump	16	161	Power Operated Valve	2358	821
Pump -HPSI Pump	8	30	Power Operated Valve -Motor	706	251
Pump -LPSI Pump	8	40	Power Operated Valve -Pneumatic	1507	564
Pump -MFW Turbine Pump	8	165	Power Operated Valve -Solenoid	145	6
Pump -TBCCW Pump	8	55	Pressure Regulating Valve	42	30
Pump -TBOCW Pump	10	117	Relief Valve	417	49
ACU	190	106	Sprinkler	112	4
Air Dryer	6	35	Filter	138	352
Chiller	16	173	Filter -Debris Filter	66	168
Compressor	8	76	Filter -Dryer Assembly	72	184
Fan	103	127	Hydrant	90	6
Traveling Screen	32	332	Strainer	309	191
Battery	29	3	Circuit Breaker	5420	152
Battery Charger	34	35	Circuit Breaker -13.8KV SG	92	24
Bus	391	168	Circuit Breaker -C1E 4.16KV	145	17
Diesel Generator	10	220	Circuit Breaker -C1E 480V LC	221	2
Inverter	30	60	Circuit Breaker -C1E 480V MCC	1024	8
Transformer	156	179	Circuit Breaker -N1E 4.16KV	128	2
Controller	209	35	Circuit Breaker -N1E 480V LC	604	24
Controller -Differential Pressure	4	2	Circuit Breaker -N1E 480V MCC	2642	72

Controller -etc	6	3	Transmitter	781	207
Controller -Flow	82	10	Transmitter -Differential Pressure	75	48
Controller -Level	32	3	Transmitter -Flow	228	58
Controller -Pressure	41	5	Transmitter -Level	136	61
Controller -Temperature	44	12	Transmitter -Pressure	210	12
Switch	1585	213	Transmitter -Temperature	132	28
Switch -Differential Pressure	248	86	Element	714	29
Switch -Flow	265	9	Element -etc	12	2
Switch -Level	276	17	Element -Flow	343	9
Switch -Pressure	359	17	Element -Temperature	357	18
Switch -Temperature	437	84	Fire Detector	61	94

7

7.

	3		4		3		4		
LPSI Pump		0.833		0.833		0.833		0.833	2
HPSI Pump		0.833		0.833		0.833		0.833	2
CS Pump		0.833		0.833		0.833		0.833	2
Spray Additive Pump						0.833		0.833	2 , 3,4
Charging Pump	0.5	0.856	0.5	0.92	0.667	1.597	0.667	1.88	3 , 4
CCW Pump	0.5	0.167	0.5	0.167	0.333	0.333	0.333	0.333	4 , 6
ESW Pump	0.5	0.167	0.5	0.167	0.5	0.167	0.5	0.167	4
FW Pump (Turbine Driven)	1		1		1		1		Turbine Driven Pump 2
FW Booster Pump	1		1		1		1		TD Pump 2
AFW Pump		0.833		0.833		1.5		1.5	4
Circulating Water Pump	0.833	0.167	0.833	0.167	0.8	0.167	0.8	0.167	6
ESW Screen Wash Pump		1.08		1.08		1.333		1.333	4
TBOCW Pump	0.5	0.167	0.5	0.167	0.667	0.333	0.667	0.333	2 , 3
TBCCW Pump	0.5	0.167	0.5	0.167	0.5	0.167	0.5	0.167	2
Diesel Generator	0.00137	1	0.00137	1	0.00137	1	0.00137	1	2 + site AAC 1
Air Compressor	0.5	1.03	0.5	0.68	0.5	0.695	0.5	0.69	2

	3		4		3		4		
ECW Chiller	0.5	0.87	0.5	0.94	0.5	0.9	0.5	0.943	4
ECW Pump	0.5	0.87	0.5	0.94	0.5	0.9	0.5	0.943	4

[3]

218

76

가 가

8

8.

()

0.0 -0.1	10	13.3	13.3
0.1 -0.2	4	5.3	18.7
0.2 -0.5	12	16.0	34.7
0.5 -1.0	13	17.3	52.0
1.0 -2.0	10	13.3	65.3
2.0 -5.0	16	21.3	86.7
5.0 -10.0	6	8.0	94.7
10.0 -50.0	4	5.3	100.0

- 0.5 – 2 23 , 31% 가

- 0.2 – 5 51 , 68% 가

- 0.2 14 , 19%가

10

- 가 5 10 , 13%가

가 가 68%

, 32%

PSA

가 chiller, diesel generator, ESW pump, charging pump

OOS

9

3

3

24

OOS

9. 3 OOS ()

OOS	1	2	3	4	5	6
	296	99	14	10		3
			139	7		
			594	724		47
&			91	205		
	296	99	838	946		50

OOS

OOS 2 99

가

가

OOS

OOS

가 3

4 ,

가

가

가

가

OOS

가

가

5.

DB

KIND

DB

DB

DB

DB

KIND

DB

PSA

RIR&A

PSR

DB framework

DB

가

framework /

가

OOS

2000) 10 24 3, 4 (-1998) 3,4 (-
250 / , 75
, 68% 가

5,6 PSA

5,6 PSA Risk -Informed In -Service Test 가
PSA RIR&A
가 3,4 2000

KEPRI, 2 2 , , ,

[1] , “ ”, KAERI/TR -2132/2002, 2002

[2] , “ DB ”, KAERI/TR -
2130/2002, 2002

[3] , “ ”, KAERI/TR -2129/2002, 2002