

가

## **Analysis of Containment Environments for Evaluating the Survivability of Severe Accident Equipments**

, , ,

ALWR

가

,  
가 , 가  
가  
가 . 가 ,  
가  
가  
가

### **Abstract**

As noted in the ALWR requirement document, a top-level program objective is to achieve increased public safety and protection of plant investment through improved design. It is required to properly conduct the severe accident management and to evaluate the environments inside the RCS and containment under severe accidents. Selecting the instruments and equipments which is needed under severe accidents and assessing their

survivability are to evaluate the availability of the equipments and instruments required during severe accidents to recover to a controllable, safe and stable state after core melt under specified containment environments. To assure increased public safety and investment protection, realistic, best-estimate analyses will be performed to assess the capability of the plant to withstand accidents beyond the licensing design basis for a set of accident sequences which are chosen based on their risk dominance. In this work, environment analyses necessary to conduct the survivability assessment of the severe accident equipment were performed for an advanced reactor which is under development.

## 1.

가 , (Equipment Survivability)  
 가 가 . 가 가  
 , (Equipment Qualification)  
 가 , 가  
 가 가 . 가  
 가  
 가 가 . 가 가  
 가 가 가  
 가 가 [1].

ALWR 가  
 . 가 ALWR  
 NRC [2]  
 가 ,  
 가  
 가 .  
 ALWR  
 . 가 4가  
 가 [1]:

1. 가 ALWR .
2. ALWR
3. 가 .
4. 가

가  
 가 ALWR  
 ALWR ALWR 1 [3]  
 1.0E-05 , 1.0E-05 가  
 NRC

가 가

가  
 가 ALWR 1  
 가 1.0E-06 /reactor-year 0.5 가  
 25 rem

ALWR 가 가  
 [1]:  
 1. 가 ( , )  
 2. ( , 가 )  
 3. ( RHR )  
 4. 가  
 5.

가

가

(Cavity Flooding System)

1

가

가

가

가

2.

2.가

가

가

가

가

F-V (Fussel-Vesely)

, RRW (Risk Reduction Worth)

RAW(Reduction Achievement Worth)

가

가

(LBLOCA),

(SBLOCA),

(TLOFW),

(SBO)

2.

가

,

가

가

가

- 1) (8가 )
    - i. : LBLOCA(0.5 ft<sup>2</sup>), SBLOCA(1"), TLOFW, SBO (4가 )
    - ii. : MAAP 가  
(4가 )
  - 2) (3가 )
    - i. LBLOCA with Containment Spray
    - ii. SBO w/o Containment Spray, w/ Cavity Flooding System
    - iii. SBO w/o Containment Spray, w/o Cavity Flooding System
  - 3) Global (2가 )
    - i. : SBLOCA ( 가 )
    - ii. Global : SBLOCA (100% Zr 가 )
- 4가 , 2가 4가 3가  
13가 가 가 .

### 3.

MAAP ,

	MAAP	IDCOR (Industry Degraded Core Rulemaking)
Program	Fauske & Associates, Inc	EPRI
1 ,	(Auxiliary Building)	
	IPE (Individual Plant Evaluation)	
가	가	가 ,
가	가	가 가 ,
	(Hydrogen Monitoring System)	15% 가 ,
	가 10%	
	).	
	가 ,	

PASS (Post Accident Sampling System)

(PASS ( 24 ) 가  
). Harsh Environment가 가

13가

가 :

- 1)
- 2)
- 3)
- 4) 가
- 5) 가
- 6) IRWST
- 7) IRWST
- 8)
- 9) IRWST
- 10)

[4]:

1) 1 ( ) : ,  
/ 가  
1 가 가

2) 2 ( ) : 가  
가  
가  
RCS  
가



가 TLOFW SBO  
가 . LOCA TLOFW  
IRWST , SBO

3.

4가  
3 가  
Bounding , ,  
. 4가 ,  
MAAP 31 .  
가,  
가 ,  
가 가  
가 가  
가

3.

가

3.

2가  
4 가  
Bounding .  
'3. ' 가  
가 ,  
가

4.

가


MAAP




가

(00- -04)


1. EPRI, Advanced Light Water Reactor Utility Requirements Document, Vol. II ALWR Evolutionary Plant, Chap.5 Engineered Safety Systems.
2. EPRI, Advanced Light Water Reactor Utility Requirements Document, Vol. II ALWR Evolutionary Plant, Chap.1.
3. NRC, Policy Statement on Severe Reactor Accidents Regarding Future Designs and Existing Plants, 50FR32138.
4. AP600 Probabilistic Risk Assessment Appendix D Equipment Survivability Assessment.




1.




(1)




(2)




(3)



(4)




(5) 가




(6) 가

2.




(7) IRWST


2.




(1)



(2)




(3)




(4)

3.



(1)



(2)

4.