

**Evaluation of LB-LOCA Mass and Energy Release Using Best-Estimate
Computer Code for Kori Unit 2**

, , , ,

150

103-16

RELAP5/MOD3.1-K

2

2

FSAR

RELAP5/MOD3.1-K

가 FSAR

가

2

Abstract

The preliminary analysis of mass and energy release(M/E) for cold leg double-ended guillotine break in Kori unit 2 is performed using best-estimate code, RELAP5/MOD3.1-K. When compared with mass and energy release data of Kori 2 FSAR, those of RELAP5/MOD3.1-K are found to be larger than those of Kori 2 FSAR, which results from the different modeling of safety injection system. However, regarding to energy release data, the comparison results show good agreement. Therefore, it is concluded that the analysis method of mass and energy release using RELAP5/MOD3.1-K and is useful for the analysis of

mass and energy release for environmental equipment qualification. To improve the present method, the model of safety injection system need to be modified to overcome the difference between the present model and Kori 2 FSAR model.

1.

가
가(Periodic Safety Review;PSR) , IAEA 11 [1] “ PSR
” 가 ,
가 .
가 .
가
가
가 , PSR
가 .
NUREG-0588[2]
 . NUREG-0588 ,
 .
2 [3] 가 .
SRP
6.2.1.3[4] . SRP 6.2.1.3
가 :
1) 102% 가 ,
2) ANS 1971 ,
3) 가 ,
4) 3% 가 ,

5) 가 ,

6)

PSR 가

가

IAEA PSR “ 가
가?” 가

RELAP5/MOD3.1-K[5]

2

2

FSAR

2

가

2. 2 가

RELAP5/MOD3.1-K

NRC RELAP5/MOD3.1[6]

CONTEMP4/MOD5[7]

, RELAP5/MOD3.1-K

2

1

2

1

RELAP5/MOD3.1-K

가

2

FSAR

2

가
가

10% 가

3.

2 2

5 . 2 2

FSAR RELAP5/MOD3.1-K

, 2 FSAR 가 .

3 2 FSAR

RELAP5/MOD3.1-K . 3 2 FSAR

370 , 가

, (Liquid carryover rate fraction)

. 2 FSAR [8]

0.8 가, 가 0.05

. RELAP5/MOD3.1-K 2 FSAR

400 3 , 400 6 가 .

가 RELAP5/MOD3.1-K

2

FSAR . 2

FSAR 59.5 psia 가 , RELAP5/MOD3.1-K CONTEMP4

가 .

4 2 FSAR

RELAP5/MOD3.1-K . 2

. 5

2 FSAR RELAP5/MOD3.1-K . 3

가 . RELAP5/MOD3.1-K

RELAP5/MOD3.1-K FSAR

, 가 .

, 370 FSAR 가 .

3 . FSAR

0.05

4.

RELAP5/MOD3.1-K 2
FSAR RELAP5/MOD3.1-K 가 FSAR
가
2

5.


2

6.


- [1] International Atomic Energy Agency, General Design Safety Principles for Nuclear Power Plants: A Safety Guide, Safety Series No., 50-SG-D11, IAEA, Vienna.
- [2] A.J. Szukiewicz, Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment, NUREG-0588, Rev.1, July 1981.
- [3] 2 , 6
- [4] NRC, Standard Review Plan, NUREG-0800, Rev.2, April 1996.
- [5] Topical Report for Best Estimate Methodology for Evaluation of Emergency Core Cooling System, , 1997 4 .
- [6] K. E. Carlson et al., RELAP5/MOD3 Code Manual, Volume I, II, III, IV and V", NUREG/CR-5535, EGG-2596, 1990.
- [7] C. C. Lin, et al., CONTEMPT4/MOD4: A Multicompartent Containment System Analysis Program, NUREG/CR-3716, BNL-NUREG-51754, March 1984.
- [8] R. M. Shepard, Topical Report for Westinghouse Mass and Energy Release for Containment Design, WCAP-8314-A, Rev.2, August, 1975.

	(FSAR)	
(MWt)	1876	1876
(K)	579.25	579.24
(kg/sec)	8952.15	8952.2
가 (MPa)	15.51	15.51
가 (m ³)	16.99	16.99
(m ³ /sec)	6.44 (Design Flow)	5.97 (Nominal Flow)
(MPa)	6.343	6.335
(m)	12.75	12.74
(kg/s)	514.7	514.19

(x 10 ⁶ ft ³)	1.44
(psia)	14.7
(°F)	50
(%)	100
(gpm)	1185
Fan Cooler	2 FSAR Data x 2.2
Passive Heat Sink	2 FSAR Data x 1.1




1. 2 RELAP5/MOD3.1-K




Blowdown period

2. 2



Post blowdown period

3 2



Blowdown period

4 2

