

Chec Family of Codes 2 가

Erosion -corrosion Analysis of Secondary Side Piping Components using Chec Family of Codes in Nuclear Power Plant

*, , , ,

150

EPRI Chec Family of Codes

가

Abstract

Pipe wall thinning due to erosion-corrosion raises severe plant and personnel safety. Effective inspection program is required to prevent piping failure caused by erosion-corrosion. Chec Family of Codes developed by EPRI was used to predict erosion-corrosion rates in piping components and to calculate the time remaining before reaching user defined acceptable wall thickness. The rate of wear rate depended on water chemistry and design factors. Erosion-corrosion evaluation by codes is to be useful to utilities.

1.

(erosion-corrosion)

가 가 (, , ,), (, pH,), (Cr, Cu, Mo)

[1]. 가 (feedwater heater) (water) 2 (water-wet steam) - 2 - [2]. 1986 Surry

2 - 가

[3]. EPRI 2 - 가
Chec Family of Codes [4] 2 - 가

가 . 2 - 가

- 가 .

2.

Chec Family of Codes EPRI

case data form, case segment data form, segment (tee, elbow, ...) component data form . A heat balance diagram, P&ID drawings, isometric drawings, spec.

A (1 a). 1(b) 가 pH - case A case B . case A 4 segment case B 6 segment (1c). 1 2 2 (a), (b), (c) .

3.

가 , pH, , , 가 pH 가 9.3 3 4 pH 9.0 9.3 . pH - 가 . Tcrit Tcrit

Tcrit .

(p), (e), (v) (r) 가 -

Tcrit . (e) 45° 90°

(e) 가 . 3 s3, s4 s5 segment

Tcrit component . 9

component 가 Tcrit . 4

10000 Tcrit component . 70000

39 component 30 가 Tcrit . 3

Tpred/Tcrit 66600 9 Tcrit 4

component Tcrit . 5 s6, s7

s8 segment component 21 가 Tcrit .

20000 component Tcrit

가 .

component

가

가

가

4.

1.

pH가 9.0

9.3

가

가

2.

-

가

,

,

가

3.

4.

-

가

- 1.G.Cragolino, "A Review of Erosion-Corrosion of Steels in High Temperature Water", proc. 3th International Symposium on Environmental Degradation of Materials in Nuclear Power systems -Water Reactors, p397(1987)
- 2.Water chemistry and Corrosion in the Steam -Water Loops of Nuclear Power Stations, Conf, ADERP, Electricite de France, Seillac, France(1980)
- 3.C.J. Czajkowski, Metallurgical Evaluation of an 18-Inch Feedwater Line Failure at the Surry Unit 2 Power Station, NUREG/GR-4868, Brookhaven National Laboratory(1987)
- 4.Chec Family of Codes User's Manual (NSAC/145L)

Table 1. Chemistry history data

Case	Amine type	pH	Oxygen(ppb)	No. of hours
A	ammonia	9.00	5	60900
	ammonia	9.30	5	39100
B	ammonia	9.00	5	40600
	ammonia	9.30	5	26000

Table 2. Design condition for piping segment

Segment name	Pressure(psig)		Temperature()		Enthalpy (Btu/lbm)
	design	operation	design	operation	
s1, s2 s3, s4, s5	400	315.3	390	363	336.14
s6, s7, s8, s9, s10	1550	1155.3	450	365	338.83

Table 3. Erosion -corrosion calculation data of segment s4 and s5

Component Name	Geometry Code	Thickness (in)			Erosion Rate (mils/year)		Component Predicted Time to Tcrit (hrs.)	
		Init.	Pred.	Tcrit	Avg.	Cur.	Tcrit	Inspetion
S4								
t1	11	0.375	0.254	0.264	16.0	10.3	-8805	
p2	61	0.375	0.302	0.264	9.6	6.2	54453	
e3	2	0.375	0.281	0.264	12.3	7.9	19537	O
v4	22	0.375	0.254	0.264	16.0	10.3	-8805	
p5	58	0.375	0.324	0.264	6.7	4.3	122229	O
e6	2	0.375	0.281	0.264	12.3	7.9	19537	
p7	52	0.375	0.314	0.264	8.0	5.1	86082	
e8	2	0.375	0.281	0.264	12.3	7.9	19537	O
p9	52	0.375	0.314	0.264	8.0	5.1	86082	
e10	2	0.375	0.281	0.264	12.3	7.9	19537	O
r11	17	0.312	0.215	0.211	12.7	8.2	4540	
e12	2	0.312	0.188	0.211	16.3	10.5	-19355	O
p13	52	0.312	0.231	0.211	10.6	6.8	26187	
S5								
p1	10	0.375	0.254	0.264	16.0	10.3	-8805	
t2	13	0.375	0.254	0.264	16.0	10.3	-8805	
e3	2	0.375	0.281	0.264	12.3	7.9	19537	O
v4	22	0.375	0.254	0.264	16.0	10.3	-8805	
p5	58	0.375	0.324	0.264	6.7	4.3	122229	O
e6	2	0.375	0.281	0.264	12.3	7.9	19537	O
p7	52	0.375	0.314	0.264	8.0	5.1	86082	
e8	2	0.375	0.281	0.264	12.3	7.9	19537	O
p9	52	0.375	0.314	0.264	8.0	5.1	86082	
e10	2	0.375	0.281	0.264	12.3	7.9	19537	O
r11	17	0.312	0.215	0.211	12.7	8.2	4540	
e12	2	0.312	0.188	0.211	16.3	10.5	-19355	O
p13	52	0.312	0.231	0.211	10.6	6.8	26187	

Table 4. Erosion -corrosion calculation data of segment s7 and s8

Component Name	Geometry Code	Thickness (in)			Erosion Rate (mils/year)		Component Predicted Time to Tcrit (hrs.)	
		Init.	Pred.	Tcrit	Avg.	Cur.	Tcrit	Inspetion
		S7						
p1	57	0.844	0.755	0.684	11.7	7.5	83034	
v2	20	0.844	0.666	0.684	23.4	15.0	-10522	
p3	70	0.844	0.666	0.684	23.4	15.0	-10522	
e4	1	0.844	0.737	0.684	14.0	9.0	51848	
e5	2	0.844	0.707	0.684	18.0	11.5	17422	O
p6	52	0.844	0.755	0.684	11.7	7.5	83034	
e7	2	0.844	0.707	0.684	18.0	11.5	17422	O
p8	52	0.844	0.755	0.684	11.7	7.5	83034	
e9	2	0.844	0.707	0.684	18.0	11.5	17422	O
p10	52	0.844	0.755	0.684	11.7	7.5	83034	
e11	2	0.844	0.707	0.684	18.0	11.5	17422	O
v12	8	0.844	0.666	0.684	23.4	15.0	-10522	
p13	58	0.844	0.769	0.684	9.8	6.3	118675	
e14	2	0.844	0.707	0.684	18.0	11.5	17422	O
p15	52	0.844	0.755	0.684	11.7	7.5	83034	
S8								
p1	57	0.844	0.755	0.684	11.7	7.5	83034	
v2	20	0.844	0.666	0.684	23.4	15.0	-10522	
p3	70	0.844	0.666	0.684	23.4	15.0	-10522	
e4	1	0.844	0.737	0.684	14.0	9.0	51848	
e5	2	0.844	0.707	0.684	18.0	11.5	17422	O
p6	52	0.844	0.755	0.684	11.7	7.5	83034	
e7	2	0.844	0.707	0.684	18.0	11.5	17422	O
p8	52	0.844	0.755	0.684	11.7	7.5	83034	
e9	2	0.844	0.707	0.684	18.0	11.5	17422	O
p10	52	0.844	0.755	0.684	11.7	7.5	83034	
e11	2	0.844	0.707	0.684	18.0	11.5	17422	O
v12	8	0.844	0.666	0.684	23.4	15.0	-10522	
p13	58	0.844	0.769	0.684	9.8	6.3	118675	
e14	2	0.844	0.707	0.684	18.0	11.5	17422	O
p15	52	0.844	0.755	0.684	11.7	7.5	83034	

<CASE_DATA_FORM>
Plant Past & Current History

Title: H5h6
Total No. Of Operating Hours: 1.c+5

Chemistry History Data

Amisc	pH value	Oxygen	No. of Hours	Fault
1	9.	5.	68988.	188.
1	9.3	5.	39188.	188.
0	0.	0.	0.	0.
0	0.	0.	0.	0.
0	0.	0.	0.	0.
0	0.	0.	0.	0.
0	0.	0.	0.	0.
0	0.	0.	0.	0.

(a)

<SEGMENT_DATA_FORM>

Design Conditions For Piping Segment

Segment Title: c13s1
 Segment Design Pressure.....(psig): 488.
 Segment Design Temperature.....(°F): 398.
 Source/Operating Pressure.....(psig): 315.2998
 Plant Config. Line Type.....(A-R,Z): a
 Plant Config. Line Number.....: 1

Source Enthalpy (Btu/lbm) or Quality: -336.14
 Sink Pressure.....(psig): 315.2998
 Insulation Thickness.....(inch): 3.9
 Insulation Thermal Conductivity (Btu/hr/ft/°F): 0.
 Absolute Roughness.....(inch): 0.

(b)

<COMPONENT_DATA_FORM>

Name.....: p1
 Comment.....:
 Geometry Code.....: 67
 Diameter.....: 16.
 Schedule/Thickness.....: 48.
 Thermodynamic State...: 363.3999
 Flow Rate.....(Milb/Hr): 3.773

Material No.: 5
 Chrome...(%): 0.
 Copper...(%): 0.
 Molybd...(%): 0.
 Sigma...(psi): 0.

R/D For Elbow.....: 0.
 Orientation.....(deg): 0.
 Orifice Size.....(in): 0.
 Valve Coefficient.....: 0.
 Pipe Length.....(in): 88.

Predicted Pressure (psig): 0.
 Predicted Quality.....: 0.

INSPECTION DATA

TBAT	Time When Measured
0.	0.
0.	0.
0.	0.
0.	0.

Inspection Status:

(c)

Fig. 1. Data entry forms (a) case data form (b) segment data form
(c) component data form




Fig. 2. Plant configuration of A nuclear power plant: (a) plant configuration
 (b) calculated line (c) segments(s_3 , s_4 , s_5 , s_6 , s_7 , s_8) of the
 calculated line




Fig. 3. Tpred/Tcrit ratio of components in segment s3, s4 and s5




Fig. 4. Cumulative no. of components time to Tcrit of segment s3, s4 and s5




Fig. 5. Tpred/Tcrit ratio of components in segment s6, s7 and s8




Fig. 6. Cumulative no. of components time to Tcrit of segment s6, s7, s8