## 2000

## Analysis model for evaluating the Corium Retention Effect by the Ex-vessel Cooling Strategy



가

가

## Abstract

Analysis model for evaluating the corium retention effect by the ex-vessel cooling strategy is developed for the Korean standard nuclear power plant using MELCOR 1.8.4 code. The ex-vessel cooling effect per the relocated corium mass fraction is analyzed. To reduce the CPU time, the core melting and relocation are facilitated, and the decay heat of the early relocated corium is modified to have same level of decay heat per the relevant core melt sequence. Thus the calculation time for the sensitivity study can be reduced. This modelling can be used to the sensitivity study for estimating the metallic & oxide mass of the core damage sequence. Preliminary analyses are performed to estimate the ex-vessel cooling effect to prevent the vessel failure for the high pressure core melt sequence. Later, the evaluation for the ex-vessel cooling effects and the metallic & oxide mass will be performed for the low pressure sequences.







가	

			•

## .

2.							
가.							
(3.81m)	10 ,	,	4			40	cell
,	lower ple	enum (	2.317m)			3,	
4	12 cell		. MELCOR				
52 cell							
	(150kg/s=2400gpm)			(	1).		
. (Ri	ng 1 Ring2)	(	LH			)	
MELCOR 1.8.	4						
2			가				1

		Ring 1	Ring 2	Ring 3	Ring 4	Ring 1	Ring 2	Ring 3	Ring 4
		25	72	40	40	48	49	40	40
R(	), m	0.5874	1.157	1.375	2.1049	0.8136	1.157	1.375	2.1049

1.

I











.

L

가 UO2

	UO <sub>2</sub> ( )	Zr ()	(	%)
100%	86	24		
UO <sub>2</sub> 40%	34.4	9.6	40%	44%
UO <sub>2</sub> 60%	51.6	14.3	60%	66%
UO <sub>2</sub> 80%	68.8	19.1	80%	84%

MELCOR 1.8.4





CORRE

PENETRATION

)

Figure 4.1.1 Lower head notalization

3.

.

가 10

		17MPa	17MPa	17M P a	< 1MPa	< 1MPa
RCS	(SDS)				* > 2.7hr	* > 2.7hr
SIT	I					
			•			
UO <sub>2</sub>	40%					
$UO_2$	60%					
$UO_2$	80%					
	$UO_2$		( );	5,151 (609	%), 3,65	9 (80%

가.

\*

TMI-2 , DCH

•

( UO<sub>2</sub>

86 ) UO<sub>2</sub> 40%, 60% 80% UO<sub>2</sub>

.

( 4 5 ).

.

CE

	(		/		)	$UO_2$
UO <sub>2</sub> 40%	82	(41	/ 41	)		34.4
UO <sub>2</sub> 60%	104	(60	/ 44	)		51.6
UO <sub>2</sub> 80%	127	(80	/ 47	)		68.8







6 UO<sub>2</sub>, UO<sub>2</sub>

I.



		UO <sub>2</sub>		
			(	)
40%	N/A < 160,000	27,900	> 36.7	
60%	116,300	11,500	29	
80%	33,200	9,900	6.5	















, 1-D

L

•



4) MELCOR



,

T

1. NUREG/CR-6119 rev. 1, "MELCOR Computer Code Manuals Version 1.8.4", SNL, Jul., 1997

.

- 2. NUREG/CR-6197, "TMI-2 Vessel Investigation Project Integration Report", INEL, Mar. 1994
- 3. NUREG/CR-6338, "Resolution of the Direct Containment Heating Issue for All Westinghouse Plants with Large Dry Containments or Subatmospheric Containments", SNL Feb., 1996
- 4., NUREG/CR-6338, "Resolution of the Direct Containment Heating Issue for Combustion Engineering Plants and Bobcock & Wilcox Plants", SNL, Nov., 1998