

KALIMER

Thermal Stress Analysis and Service Limit Check for KALIMER Reactor Internal Structures

, , , ,

150

KALIMER

ASME Code Case N-201-4

. Level A/B

가

Abstract

In this paper, thermal stress analyses and service limit checks using ASME Code Case N-201-4 for KALIMER reactor internal structures are carried out in case of pre-determined steady state condition. From the stress analysis, severe thermal stresses occurred at the connecting parts between the separation plate/the baffle plate and the support barrel/the RV liner. From the service limit checks for the Level A and B Service Loadings using the elastic analysis method, the reactor internal structures satisfy the load-controlled quantities when the thermal barrier is introduced, but do not satisfy the deformation-controlled quantities. Therefore, the modification of the analysis conditions and the detail inelastic analysis are required to check the service limits.

1.

KALIMER(Korea Advanced Liquid Metal Reactor)

150MWe

가

530°C

가 (1)

(530°C)

(386°C) 가

(2)

가 KALIMER
(Seismic isolation design)⁽³⁾가

KALIMER

3

가

ASME
(800°F)

가 427°C

ASME Code Section III, Subsection NG 가

ASME Code Case N-201-4⁽⁴⁾

KALIMER

Level

A/B

2. KALIMER

Fig. 1 I-DEAS

KALIMER

3

(Inlet Plenum), (Support Barrel), (RV Liner),
 (Baffle Plate), (Separation Plate), (Flow Guide)
 KALIMER (Core Support),

Fig. 2




Fig. 1 Conceptually Designed KALIMER RI




Fig. 2 Primary Sodium Flow Path

Heat Exchanger) 2 (386°C)
2 (Electro Magnetic Pump) (530°C)
(Primary Intermediate

가
KALIMER
가

가

/ / /
가

8
KALIMER
(Drive fuel)

가

가

1.5cm

10cm

316 SS
가

3. 가
3.1

Fig. 3

/ / /
1/4

ANSYS 5.5
SOILD70

(5)

SOLID45

/ / /

1/4

1

1.2m

3.2

/ / /
 (PSDRS)
 PSDRS
 PSDRS
 (Convection), (Conduction), (Radiation)

Fig. 4

COMMIX

KALIMER




Fig. 3 Finite Element Model




Fig. 4 Thermal Boundary Conditions

3.1

520°C

420°C
386°C

(Bulk temperature) 가

Fig. 4

500°C 가

가

PSDRS

가

Fig. 4

3

가

/ / /

3.3

Fig. 5

가

Fig. 6

가





Fig. 5 Calculated Temp. Distributions

Fig. 6 Calculated Temp. Distribution at SP

3.4

Fig. 7

8 ~ Fig. 12

Fig.

(1)

Fig. 8

(2)

Fig. 9

Fig. 10

(3)

. Fig.

11

(4)

2 가

가

. Fig. 12

(5)

3

Table 1

ASME

Table 1. Calculated Thermal Stress Intensity and Strain for Steady State Condition

	With Thermal Barrier, (MPa)					W/O Thermal Barrier, (MPa)				
	No. 1	No. 2	No. 3	No. 4	No. 5	No. 1	No. 2	No. 3	No. 4	No. 5
Membrane	21.3	49.3	51.4	91.4	26.3	48.6	54.2	58.0	118.6	26.6
Bending	55.7	144.5	109.8	127.9	125.5	106.4	165.4	125.2	151.6	135.1
Total	66.4	152.7	113.3	130.6	127.4	105.0	173.2	129.2	151.6	137.1
e_s (%)	0.059	0.147	0.143	0.146	0.167	0.092	0.166	0.162	0.166	0.178




Fig. 7 Check Part of Service Limits

Fig. 8 Stress Intensity Contour Around No.1





Fig. 9 Stress Intensity Contour around No.2

Fig. 10 Stress Intensity Contour Around No.3




Fig. 11 Stress Intensity Contour Around No.4




Fig. 12 Stress Intensity Contour Around No.5

4. ASME

Section III, Division 1 – NG	가	ASME Code
가	427°C (800 °F)	KALIMER
800°F		
ASME Code Section II, Part D		
Section III (CSS)	(Rules)	ASME
Section II, Part D		
Subsection NG	ASME Code Case N-201-4	Part A
Part B /		
ASME Code Case N-201-4	Part A	Part B
	Subsection NG	
Part A	Stress-rupture	가 가
	Appendix XIX	Time-at-temperature limits
	Stress-rupture	
Part B	Stress-rupture	Subsection NG
	Part A	Appendix XIX
	Part A	Part B
	Stress-rupture	Part B
	(Design Acceptability)	Code NG(NG) Code
Case N-201-4(N-201)가	NG	ASME Section II,
Part D, Subpart 1	Table 2A, 2B	4 (S _m)
	N-201	
	NG	N-201

(Tresca)

Flow rule

ASME Code Case N-201

가
2가 ,

N-201 가
(NG-3220) , (Appendix Y)

NG-3000

Appendix Y 가 ()

(Appendix Y) (NG-3220) ,

4.1

(P_m , P_b ,
 F , P_i)가
(,)
가 . (Fig. NG-3220.1)
Table NG-3217-1

NG Table

Level A/B

(Operating Basis Earthquake)

(6)

Check 1:

$$S_{mt} (t) (T) P_m \leq S_{mt} t T \quad (1)$$

KALIMER

30

$T=455^\circ\text{C}$

$T=500^\circ\text{C}$ 가 S_{mt} 108MPa 106MPa .

Table 2

(1)

(4) 118.6MPa

(1)

Table 2. Service Limit Check for Load-Controlled Quantities

	Check Part	Check 1 ($P_m \leq S_m$)		Check 2 ($P_m + P_b \leq K S_m$)		Check 3 ($P_m + P_b / K_t \leq S_t$)	
		P_m	S_m	$P_m + P_b$	$K S_m$	$P_m + P_b / K_t$	S_t
With Thermal Barrier	No. 1	21.3	108	30.1	159	28.4	140
	No. 2	49.3	108	80.2	159	74.0	140
	No. 3	51.4	106	63.5	159	61.1	124
	No. 4	91.4	108	122.1	159	116.1	140
	No. 5	26.3	106	38.4	159	36.0	124
W/O Thermal Barrier	No. 1	48.6	108	57.4	159	55.7	140
	No. 2	54.2	108	85.1	159	78.9	140
	No. 3	58.0	106	70.1	159	67.7	124
	No. 4	118.6	108	149.5	159	143.3	140
	No. 5	26.6	106	38.7	159	36.3	124

* P_m : Primary membrane stress due to thermal load of steady state condition

* P_b : Primary bending stress due to OBE load

Check 2 :

$$P_m + P_b \leq K S_m \tag{2}$$

S_m

K

$$K = \frac{F_{(fully\ plastic)}}{F_{(initial\ plastic)}} = \frac{\quad}{\quad} \tag{3}$$

(3)

가

$K=1.5$ 가

Table 3

No.4

가

20%

Check 3 :

$$P_m + P_b / K_t \leq S_t \tag{4}$$

S_t

(T)

(t)

(4)

K_t

$$K_t = (K + 1) / 2 \tag{5}$$

Check 2

$K=1.5$

$K_t=1.25$

Check 1

가

KALIMER

$T=455^\circ\text{C}$

$T=500^\circ\text{C}$

S_t

ASME Code Case N-201-4

Table

5.3B

$S_t=140\text{MPa}, S_t=124\text{MPa}$

Table 3

가
Check 3

가 (4)
(No.4)

4.2

(427°C)

4.1

, 2) , 1) , 3) - 가, 4) , 5) , 6) Isochronous -

Check 1 :

1%

$$e \leq 1.0\%$$

(6)

Table 1

1.0%

가

(6)

Check 2 :

가

$$\text{Membrane } e_m \leq 1.0\% , \text{ Bending } e_b \leq 2.0\% , \text{ Local } e_L \leq 5.0\% \quad (7,8,9)$$

가 (Test No. A-1, A-2, A-3) 가 가

Test No. A-1

$$X + Y \leq S_a / S_y \quad (10)$$

$$X \equiv (P_m + P_b / K_t)_{\max} \div S_y , Y \equiv (Q_R)_{\max} \div S_y \quad (11,12)$$

(10) S_y

2 S_y

$S_y=120\text{MPa}(455^\circ\text{C}),$

$S_y=118\text{MPa}(500^\circ\text{C})$. S_a 10^4

$$\begin{aligned}
 & 1.25S_t, \quad S_y, \quad S_a = \text{Min}[1.25S_t, S_y] \\
 & = \text{Min}[1.25 \times 142 \text{MPa}, 120 \text{MPa}] = 120 \text{MPa} \\
 & \text{Min}[1.25 \times 135 \text{MPa}, 118 \text{MPa}] = 118 \text{MPa} \quad (10) \\
 & S_a/S_y = 1.0
 \end{aligned}$$

(12) $(Q_R)_{\text{max}}$
 (Maximum range of secondary stress intensity)

(Table 1)

가 Startup

Hotstandby

가

Table 3 (10)

가	가	(No.4)	X+Y
가	14%	(No.3)	12%
가			

Table 3. Service Limit Check for Deformation- Controlled Quantities

	Check Part	Check 1 ($X + Y \leq S_a / S_y$)	
		X + Y	S_a / S_y
With Thermal Barrier	No. 1	0.23 + 0.29 = 0.52	1
	No. 2	0.62 + 0.79 = 1.41	1
	No. 3	0.51 + 0.50 = 1.01	1
	No. 4	0.97 + 0.30 = 1.27	1
	No. 5	0.30 + 0.84 = 1.14	1
WO Thermal Barrier	No. 1	0.47 + 0.48 = 0.95	1
	No. 2	0.65 + 0.93 = 1.58	1
	No. 3	0.57 + 0.57 = 1.14	1
	No. 4	1.19 + 0.28 = 1.47	1
	No. 5	0.31 + 0.92 = 1.23	1

Test No. A-2

$$X + Y \leq 1 \quad (13)$$

$(Q_R)_{\text{max}}$ 가

가 ASME Code Case N-201-4 Table Y-1323

(13)

Type 316 SS

가 544°C(1011°F)

500°C

(13)

Test No. A-1

$S_a/S_y = 1.0$

Table 3

Test No. A-3

NG-3222

가

$$\sum_i t_i / t_{id} \leq 0.1 \quad (14)$$

t_i

T_i 가

$T_i = 1.5S_{y|T}$ 30 가 $t_i = 2.628 \times 10^5 \text{hr}$. t_{id}
 ASME Code Case N-201-4 Fig.5.5
 $T = 500^\circ\text{C}$ $1.5S_{y|T} = 180\text{MPa}(26.1\text{ksi})$. N-201-4

Fig.5.5 Stress-to-rupture

$t_{id} = 4.61 \times 10^5 \text{hr}$ (14) $\sum_i t_i / t_{id} = 0.57 > 0.1$

4.

KALIMER

ASME Code

Case N-201-4

ASME
Level A/B Service Loadings

- 가 가

1. C. K. Park, et.al, "KALIMER Design Concept Report," KAERI/TR-888/97, *Korea Atomic Energy Research Institute*, 1997.
2. G. H. Koo, et.al, " Study on Application of 3-D Seismic Isolation Design to KALIMER Reactor Structure," KAWERI/TR-1065/98, *Korea Atomic Energy Research Institute*, 1998.
3. G. H. Koo, J. H. Lee, and B. Yoo, "Seismic Response Analyses of Seismically Isolated Structures Using the Laminated Rubber Bearings," *Journal of the Korean Nuclear Society*, Vol.30, No.5, pp.387-395, 1998.
4. ASME Boiler and Pressure Vessel Code, Section III, Division 1 – Subsection NG, Core Support Structures, 1992 Edition, *ASME*, 1992.
5. ANSYS User' s manual for Version 5.5, Volume I,II,III, *Swanson Analysis Systems, Inc.*
6. , , ;" KALIMER ;"
 , , 1999.