

한국원자력학회 2020 추계학술발표회, 12월 16일~18일

# Containment Pressure and Distribution of Fission products for SMART-100 under the SLOCA with ERVC and Spray using MELCOR1.8.6

12/17//2020

박종화\*, 김상호, 함재현, 박래준


원자력안전연구소 디지털가상원전기술개발부 사고감시대처연구실

**한 국 원 자 력 연 구 원**

# Assumptions

- SLOCA occurs at zero second !
- All PRHRs, PSI system are not function
- SRV discharges to the bottom of Mid-CPRSS
- CPRSS can vent to IRWST through Pressure discharge line, depending on the difference of their pressures
- If the pressure of LCA is greater than 1.6 bar, SIT building vent to IRWST through ECT-HX tubes. (if not, close)
- **ADS starts vent to RRT directly & path from SIT-BD to RRT opens at 30 min after SAMG condition**
- **The Size of diameters for the path from SIT-BD to RRT were modified to 6 inch**
- **At 30 min after SAMG condition, the vent from SIT-BD to IRWST through ECT will be closed.**
- ERVC was activated from two IRWSTs to the cavity at 30 min after SAMG condition
- Detail injection axial levels into the pool in IRWST and RRT are not determined yet.
- Design basis leak rate from the containment was modeled .
- Calculation was performed up to ~300000 sec (3.47 day)
- **LCA was subdivided into 5 CVs, heat structures in CPRSS was included and new flow path from Lid was included**
- **LCA was blocked against the ingress of water from ERVC**

# Nodalization of SMART100 for MELCOR




# SBLOCA with ERVC Sequence summary Table

\* PSI (SIT, CMT), PRHR are not working.


Events <sup>Ⓛ</sup>	Time (seconds) <sup>Ⓛ</sup>
SBLOCA occurrence <sup>Ⓛ</sup>	0 <sup>Ⓛ</sup>
CSL valve open ( $P_{LCA} > 1.6 \text{ bar}$ ) <sup>Ⓛ</sup>	44 <sup>Ⓛ</sup>
Reactor core, RCP, and MFWP trip <sup>Ⓛ</sup>	150 <sup>Ⓛ</sup>
Core top exposure <sup>Ⓛ</sup>	1,081 <sup>Ⓛ</sup>
Core bottom dry-out <sup>Ⓛ</sup>	8,631 (2.3 hours) <sup>Ⓛ</sup>
Oxidation start <sup>Ⓛ</sup>	10,800 (3.0 hours) <sup>Ⓛ</sup>
Candling start <sup>Ⓛ</sup>	11,800 (3.2 hours) <sup>Ⓛ</sup>
CSL valve close <sup>Ⓛ</sup>	
Valve on pipe line from SIT room to RRT open <sup>Ⓛ</sup>	
ADS pipe line valve open <sup>Ⓛ</sup>	12,040 (3.3 hours) <sup>Ⓛ</sup>
CFS pipe line valve open <sup>Ⓛ</sup> (30 minutes after SAMG entry) <sup>Ⓛ</sup>	
Massive corium relocation to lower head <sup>Ⓛ</sup>	28,250 ~ 30,350 (7.8 ~ 8.4 hours) <sup>Ⓛ</sup>
Lower plenum dry-out <sup>Ⓛ</sup>	65,557 (18.2 hours) <sup>Ⓛ</sup>
Massive corium relocation to lower head <sup>Ⓛ</sup>	92,300 (25.6 hours) <sup>Ⓛ</sup>
RRT pool boiling start <sup>Ⓛ</sup>	210,300 (58.4 hours) <sup>Ⓛ</sup>
Reactor vessel failure by creep rupture <sup>Ⓛ</sup>	N/A <sup>Ⓛ</sup>
Molten-Core Corium Interaction start <sup>Ⓛ</sup>	N/A <sup>Ⓛ</sup>

\* SAMG condition =  $T_{\text{core-exit}} > 923.15 \text{ K}$


# Collapsed Liquid Level in RPV during SBLOCA




# Temperature of Core Exit Region



# Mass of relocated-corium into Lower Plenum




# Reactor Pressure Vessel Pressures







# Containment Pressure during SBLOCA with ERVC



# Containment Pressure Change by the Operation of Spray and its Droplet Temperature (323K, 313K)



# Gas mole fraction in Containment




# Categorized spaces for the distribution of released fission product in SMART100

Type no. <sup>o</sup>	Space <sup>o</sup>
1 <sup>o</sup>	RPV <sup>o</sup> (including primary side of SG and pressurizer) <sup>o</sup>
2 <sup>o</sup>	LCA <sup>o</sup>
3 <sup>o</sup>	Water tanks <sup>o</sup> (IRWST, RRT, CMT, and SIT) <sup>o</sup>
4 <sup>o</sup>	UCA <sup>o</sup>
5 <sup>o</sup>	PRHRS loop, Secondary side of SG <sup>o</sup>
6 <sup>o</sup>	CDL, loop from SIT room to RRT <sup>o</sup>
7 <sup>o</sup>	Turbine <sup>o</sup>
8 <sup>o</sup>	Environment <sup>o</sup>

# Release Fraction at 72 hrs after SBLOCA occurrence


class	Type-1	Type-2	Type-3	Type-4	Type-5	Type-6	Type-7	Type-8
Cs (2)	0.22	0.459	0.112	0.261	0.0	1.7E-4	0.0	2.59E-5
Ba (3)	4.93E-3	6.0E-3	3.36E-3	2.51E-3	0.0	6.11E-7	0.0	2.05E-7
Te (5)	0.298	0.387	0.102	0.235	0.0	1.38E-4	0.0	2.35E-5
Mo (7)	2.81E-2	7.15E-2	5.8E-2	9.94E-3	0.0	1.07E-5	0.0	1.23E-7
CsI(16)	0.168	4.03E-1	0.1	0.252	0.0	1.24E-4	0.0	2.52E-5

# Release Fraction of fission product class 16 (CsI) during SRI OCA



Type no.	Space
1	RPV (including primary side of SG and pressurizer)
2	LCA
3	Water tanks (IRWST, RRT, CMT, and SIT)
4	UCA
5	PRHRS loop, Secondary side of SG
6	CDL, loop from SIT room to RRT
7	Turbine
8	Environment

# CsI release fraction to the environment depending on the operation of backup spray.



# Summary of the results

- Release fraction of volatile fission product such as Cs, Te, CsI to the environment by the rate of design leak rate are in the order of minus five to ten but the less volatile fission product such as Ru Ce La, U are in the order of minus ten to ten or less.
- Consequently, the amount of fission product release to the environment during the SBLOCA with ERVC and the backup spray was shown as negligible.
- In case of the operation of backup spray, the important parameter to control the containment pressure was the temperature of the spraying droplet. Therefore, it is necessary to equipped with the system that can control the temperature of spraying droplet.
- In case of spraying with 313 K of droplet temperature, the containment pressure continues to increase up to 1.49 bar with maximum. Thereafter, the pressure was stabilized at near 1.475 bar.

- end -