

Severe Accident Modeling Under Extended SBO for Apr1400

Udrescu Alexandra-Maria, Abd El Rahman Abou El Ala and Aya Diab

NUCLEAR THERMAL-HYDRAULIC AND ACCIDENT ANALYSIS LABORATORY, NUCLEAR POWER PLANT DEPARTMENT

KEPCO International Nuclear Graduate School (KINGS)

Contents

Introduction

Research Objective & Plan

Methodology

RELAP System Nodalization

SDCDAP & COUPLE Model

SBO Scenario

Model Assumptions

Base Case Results

Safety Analysis


Depressurization Timing

Uncertainty Quantification Results

Conclusion

Introduction

- Fukushima accident revealed some **vulnerabilities** of existing nuclear power plants (NPPs under) an **extended Station Black Out (SBO)**.
- This necessitates strengthening the plants' coping capability by developing appropriate **Severe Accident Management (SAM)** strategies.
- The **In-Vessel Retention (IVR)** Strategy stands as one of the key SAM strategies aiming to ensure the retention of the corium and fission products in the Reactor Pressure Vessel (RPV) by preventing the vessel failure.



Research Objective

- This thesis aims to understand the **complex phenomena** underlying a severe accident which jeopardize the integrity of the reactor pressure vessel.
- This is a basic step towards understanding the challenges of successful implementation the **IVR strategy** for APR1400 especially in consideration of both **epistemic** (phenomena-related) and **aleatory** (scenario-related) **uncertainties**.
- The goal is to identify the **success window** that guarantees the **integrity of RPV** is maintained in the event of a severe accident.

Research Plan

Milestone 1

Base
Case

Unmitigated
SBO

Milestone 2

Depressurization + Injection

High Level Candidate Actions
for In-Vessel SAM Strategy

Milestone 3

Phenomenological
Uncertainties

Scenario-Related
Uncertainties

Uncertainty Quantification


**Basic phenomena
underling the sever
accident initiated by
unmitigated SBO**

**Impact of high-level
candidate action
implementation for in-
vessel SAM**


**Uncertainty
quantification in order to
assess the IVR strategy
and identify the success
window**

Methodology


SYSTEM DESCRIPTION AND SCENARIO




COMPUTATIONAL TOOL



DECISION MAKING






RELAP System Nodalization




SCDAP Core Model

1. Fuel road 2. Control road 3. Fuel road 4. Control road 5. Fuel road 6. Control road 7. Fuel road 8. Control road 9. Fuel road 10. Control road




| | | | |
|---------|---|-------|----|
| Chan ID | 1 | # FAs | 1 |
| Chan ID | 2 | # FAs | 36 |
| Chan ID | 3 | # FAs | 64 |
| Chan ID | 4 | # FAs | 76 |
| Chan ID | 5 | # FAs | 64 |

RELAP System Nodalization



COUPLE Model




SBO Scenario

| LOSS OF OFFSITE POWER | REACTOR TRIP | EMERGENCY DIESEL GENERATOR | SBO INDUCED BY LOOP | AAC POWER | DELIVER FW AND STEAM REMOVAL | RCP SEAL INTEGRITY | OFFSITE POWER RECOVERY | DELIVER FW AND STEAM REMOVAL AFTER OFFSITE POWER RECOVERY | SAFETY DEPRESSURIZATION | SAFETY INJECTION | NO | CLASS |
|-----------------------|--------------|----------------------------|---------------------|-----------|------------------------------|--------------------|------------------------|-----------------------------------------------------------|-------------------------|------------------|-----|---------|
| LOOP | RT | DG | SBO | AAC | SHR | RCPSEAL | RAC | SHR-RAC | BLEED | FEED | | |
| | | | | | | | | | | | O1 | OK |
| | | | | | SHR-LO | | | | | FEED-SI | O2 | OK |
| | | | | | | | | | BLEED-PO/AD | | O3 | CD |
| | | | | | | | | | | | O4 | CD |
| | | | | | | | | | | | O5 | OK |
| | | | | | | RCPSEAL | | | | FEED-SI | O6 | OK |
| | | | | | | | | | | | O7 | CD |
| | | | | | SHR-AC | | | | | FEED-SI | O8 | OK |
| | | | | | | | | | BLEED-PO/AD | | O9 | CD |
| | | | | | | | | | | | O10 | CD |
| | | DG | SBO | | | | | SHR-RAC | | | O11 | OK |
| LOOP | | | | | | | | | | | O12 | CD |
| | | | | | | | RAC | | | | O13 | CD |
| | | | | | | RCPSEAL | | | | | O14 | CD |
| | | | | AAC | SHR-TD | | | | | | O15 | CD |
| | RT | | | | | | | | | | O16 | TR-ATWS |


Model Assumptions

- All AC power and all equipment powered by AC power shall not be available.
- All AAC and emergency diesel generators shall not be available.
- The FLEX portable equipment should be aligned at 2 hours.
- The plant should provide feed and bleed to cope with severe accident conditions.
- Primary injection and secondary injection should be provided to cope with severe accident conditions.
- The operator action is expected within 30 minutes from SAM entrance.


Base Case Results



POSRVs cycling vs. RCS pressure



SGs level and CET



Hydrogen production rate

CET

Base Case Results – Core Map

| Fuel rod component SCDAP component Axial node # | 1 | 3 | 5 | 7 | 9 |
|-------------------------------------------------------|---|---|---|---|---|
| 20 | I | I | I | I | I |
| 19 | I | I | I | I | I |
| 18 | I | I | I | I | I |
| 17 | I | I | I | I | I |
| 16 | I | I | I | I | I |
| 15 | I | I | I | I | I |
| 14 | I | I | I | I | I |
| 13 | I | I | I | I | I |
| 12 | I | I | I | I | I |
| 11 | I | I | I | I | I |
| 10 | I | I | I | I | I |
| 9 | I | I | I | I | I |
| 8 | I | I | I | I | I |
| 7 | I | I | I | I | I |
| 6 | I | I | I | I | I |
| 5 | I | I | I | I | I |
| 4 | I | I | I | I | I |
| 3 | I | I | I | I | I |
| 2 | I | I | I | I | I |
| 1 | I | I | I | I | I |

RELAP volume 230000000 220000000 221000000 222000000 223000000

Intact core configuration

| Fuel rod component SCDAP component Axial node # | 1 | 3 | 5 | 7 | 9 |
|-------------------------------------------------------|---|---|---|---|---|
| 20 | L | I | I | I | I |
| 19 | I | I | I | I | I |
| 18 | I | I | I | I | I |
| 17 | I | I | I | I | I |
| 16 | I | I | I | I | I |
| 15 | I | I | I | I | I |
| 14 | I | I | I | I | I |
| 13 | I | I | I | I | I |
| 12 | I | I | I | I | I |
| 11 | I | I | I | I | I |
| 10 | I | I | I | I | I |
| 9 | I | I | I | I | I |
| 8 | I | I | I | I | I |
| 7 | I | I | I | I | I |
| 6 | I | I | I | I | I |
| 5 | I | I | I | I | I |
| 4 | I | I | I | I | I |
| 3 | I | I | I | I | I |
| 2 | I | I | I | I | I |
| 1 | I | I | I | I | I |

RELAP volume 230000000 220000000 221000000 222000000 223000000

First degradation of the core configuration

| Fuel rod component SCDAP component Axial node # | 1 | 3 | 5 | 7 | 9 |
|-------------------------------------------------------|---|---|-------|---|---|
| 20 | L | I | I | I | I |
| 19 | L | L | I | I | I |
| 18 | L | I | I | I | I |
| 17 | L | L | I | I | I |
| 16 | L | I | I | L | I |
| 15 | L | L | V | P | L |
| 14 | L | L | xxMxx | L | I |
| 13 | L | L | P | I | L |
| 12 | L | L | L | I | L |
| 11 | L | I | I | I | I |
| 10 | I | I | I | I | I |
| 9 | I | L | I | L | I |
| 8 | I | I | I | I | I |
| 7 | I | I | I | I | I |
| 6 | I | I | I | I | I |
| 5 | I | I | I | I | I |
| 4 | I | I | I | I | I |
| 3 | I | I | I | I | I |
| 2 | I | I | I | I | I |
| 1 | I | I | I | I | I |

RELAP volume 230000000 220000000 221000000 222000000 223000000

First in-core molten pool relocation and metallic blockage configuration

| Fuel rod component SCDAP component Axial node # | 1 | 3 | 5 | 7 | 9 |
|-------------------------------------------------------|-------|-------|-------|-------|-------|
| 20 | V | P | L | P | L |
| 19 | V | V | P | P | P |
| 18 | V | V | L | P | L |
| 17 | V | V | P | P | P |
| 16 | V | V | P | V | P |
| 15 | V | V | V | V | P |
| 14 | V | V | V | V | P |
| 13 | V | V | V | V | V |
| 12 | V | V | V | V | V |
| 11 | V | V | V | V | V |
| 10 | V | V | V | V | V |
| 9 | V | V | V | V | V |
| 8 | V | V | V | V | V |
| 7 | xxMxx | xxMxx | xxMxx | xxMxx | xxMxx |
| 6 | xxMxx | xxMxx | xxMxx | xxMxx | xxMxx |
| 5 | xxMxx | xxMxx | xxMxx | xxMxx | xxMxx |
| 4 | xxMxx | xxMxx | xxMxx | xxMxx | xxMxx |
| 3 | xxMxx | xxMxx | xxMxx | xxMxx | xxMxx |
| 2 | xxMxx | xxMxx | xxMxx | xxMxx | xxMxx |
| 1 | P | P | P | P | P |


RELAP volume 230000000 220000000 221000000 222000000 223000000

In-core molten pool configuration right before the slumping


| Fuel rod component SCDAP component Axial node # | 1 | 3 | 5 | 7 | 9 |
|-------------------------------------------------------|---|---|---|---|---|
| 20 | V | P | P | P | L |
| 19 | V | V | V | P | P |
| 18 | V | V | V | P | L |
| 17 | V | V | V | P | P |
| 16 | V | V | V | V | P |
| 15 | V | V | V | V | P |
| 14 | V | V | V | V | V |
| 13 | V | V | V | V | V |
| 12 | V | V | V | V | V |
| 11 | V | V | V | V | V |
| 10 | V | V | V | V | V |
| 9 | V | V | V | V | V |
| 8 | V | V | V | V | V |
| 7 | V | V | V | V | V |
| 6 | V | V | V | V | V |
| 5 | V | V | V | V | V |
| 4 | V | V | V | V | V |
| 3 | V | V | V | V | V |
| 2 | V | V | V | V | V |
| 1 | P | P | P | P | P |

RELAP volume 230000000 220000000 221000000 222000000 223000000

Core configuration right after the molten pool relocation to lower head



Base Case Results – Molten Pool Configuration



Base Case Results - Summary

Accident progression

| Time (hh:mm) | Sequence |
|--------------|----------------------------------------------------------------------------------|
| 00:00 | Reactor TRIP Turbine TRIP RCPs TRIP FWPs TRIP MSIVs TRIP TIV TRIP |
| 00:01 | MSSVs START CYCLING |
| 00:50 | MSSVs STOP CYCLING SGs DRYOUT |
| 01:03 | POSRVs START CYCLING |
| 01:05 | Boiling START |
| 01:11 | Core UNCOVERY |
| 01:46 | Severe accident ENTRANCE |
| 02:03 | Core DAMAGE |
| 02:18 | Core DRYOUT |
| 02:23 | First Molten Pool FORMATION |
| 03:05 | Molten Pool Final Configuration |
| 03:06 | Molten Pool SLUMPED |
| 03:49 | Molten Pool Crust FAILURE |
| 03:58 | RPV FAILURE |


In-core molten pool parameters

| Parameter | Value |
|---------------------------------------------------------------------|---------|
| Effective radius of pool, m | 1.9399 |
| Volume of molten pool, m ³ | 15.289 |
| Temperature of molten pool, K | 3156.56 |
| Total heat generated in pool, MW | 68.282 |
| Total mass of UO ₂ in pool, kg | 106670 |
| Total mass of oxidic Zr, kg | 11330.6 |
| Total mass of metallic Zr, kg | 3084.6 |
| Mass of liquefied material in partially liquefied porous debris, kg | 775.22 |
| Liquidus temp of material, K | 2873 |


Molten pool configuration in lower head

| Constituent | Slumped mass, kg | Atomic fraction | Mass in liquefied debris, kg |
|-------------------|------------------|-----------------|------------------------------|
| Zircaloy | 1245.57 | 0.130693 | 24.564 |
| Silver | 3865.93 | 0.338654 | 158.80 |
| Uranium dioxide | 12168.6 | 0.430335 | 672.59 |
| Zirconium dioxide | 1292.28 | 0.100318 | 71.537 |

Safety Margin Evaluation




Uncertainty Quantification Framework



Depressurization Timing

- 131 cases have been simulated to identify the impact of the depressurization timing on the accident progression and the vessel failure.
- The depressurization timing varied between 30 minutes from the SAM entrance, considering operator's action margins, and almost 4 hours correspondent to the time of vessel failure for the base case.



Uncertainty Quantification

- To ensure the success of the intended IVR strategy, it is essential to quantify the underlying uncertainties given that the plant behavior is not equally influenced by all processes and phenomena that occur during the accident progression.
- The number of uncertainties considered for this particular problem had been limited by identifying and ranking the phenomena with respect to their influence on figures of merit. In other words, the top-down approach is adopted using PIRT.

Uncertainty Parameters

Phenomena related uncertainty parameters


| No. | Parameter | Lower Boundary | Mean | Upper boundary | PDF |
|-----|-------------------------------------------------------------------------------------------------|----------------|-------|----------------|---------|
| 1 | Failure temperature of oxide shell (K) | 2300 | 2475 | 2650 | Uniform |
| 2 | Fraction of oxidation of fuel rod cladding for stable oxide shell | 0.2 | 0.4 | 0.6 | Uniform |
| 3 | Hoop strain threshold for double sided oxidation | 0.02 | 0.045 | 0.07 | Uniform |
| 4 | Fraction of surface area covered with drops that results in blockage that stops local oxidation | 0.2 | 0.3 | 0.4 | Uniform |
| 5 | Velocity of drops of cladding material slumping down outside surface of fuel rod (m/s). | 0.5 | 0.75 | 1 | Uniform |
| 6 | Hoop Strain at which Rupture of Fuel Cladding Occurs | 0.15 | 0.165 | 0.18 | Uniform |
| 7 | Transition Strain | 0.182 | 0.192 | 0.202 | Uniform |

Aleatory uncertainty parameters

| No. | Parameter | Lower Boundary | Mean | Upper boundary | PDF |
|-----|------------------------------------|----------------|--------|----------------|---------|
| 8 | Primary depressurization time (s) | 8650 | 11350 | 15850 | Uniform |
| 9 | Discharge coefficients for POSRVs | 0.95 | 0.975 | 1 | Uniform |
| 10 | SITs accumulator temperature (K) | 335.7 | 373 | 410.3 | Uniform |
| 11 | SITs accumulator loss coefficient | 15.93 | 17.7 | 19.47 | Uniform |
| 12 | SITs accumulator junction area (m) | 0.18702 | 0.2078 | 0.22858 | Uniform |
| 13 | FLEX accumulator temperature (K) | 311 | 342.1 | 373.2 | Uniform |
| 14 | FLEX accumulator loss coefficient | 15.93 | 17.7 | 19.47 | Uniform |
| 15 | FLEX accumulator junction area (m) | 0.0072 | 0.008 | 0.0088 | Uniform |

Uncertainty Quantification Results

- A number of 800 cases were simulated to quantify the uncertainties.
- Only for 17% of the cases the vessel failure occurred.
- The margin of vessel failure time ranges from 6 hours 45 and 7 hours 15 minutes, approximately ± 15 minutes from the vessel failure time of the nominal case (7 hours 2 minutes).



UQ for Depressurization Time and UQ for RPV Failure Time
 30 minutes from SAMV Failure Time

Uncertainty Quantification Results

- For **35.875%** of cases, no vessel failure was observed. The high-level candidate actions provided enough cooling the molten pool material which re-solidified and did not impose enough stress on the RPV to produce a vessel failure.
- For the last **47.127%** of the cases, no vessel failure was observed. For **63.925%** of these cases, the relocation was prevented, all the material re-solidified in the core region and no slumping to the lower head occurred. And for the remaining **36.075%** of the cases, only a very small amount of core material slumped to the lower head.

Conclusion

- Proper implementation of the SAMG high-level candidate actions related to the in-vessel phase can maintain the vessel structural integrity and therefore the risk associated with the vessel failure can be minimized.

Conclusion - 1

- To increase the efficiency of the IVR strategy it is recommended for the operator to depressurize within 30 minutes from the SAM entrance. The early opening of the POSRVs help decelerate the progression of the severe accident by reducing the rate of in-core molten pool formation and consequently delaying the relocation of the molten corium.

Conclusion - 2

- The external injection flow rate should be much more than the discharged flow rate of the POSRVs to have any positive impact on the accident progression. For the investigated cases, whenever the difference between the two flow rates was not considerable, the vessel failure was observed more often. Another point that needs to be highlighted is that a large depressurization rate accelerates the core degradation especially for cases when the injection was not capable to replenish the released inventory.

Conclusion - 3

- For the investigated cases, when the depressurization was applied as early as half an hour from SAMG entrance, the vessel failure can be delayed to 7 hours 2 minutes with a margin of ± 15 minutes given the key phenomenological uncertainties investigated. With implementation of enough external water injection, it is perceived that the vessel failure can be further delayed. However, this was not investigated in this thesis.

Reference

1. W. Ma, Y. Yuan and B. R. Sehgal, In-Vessel Melt Retention of Pressurized Water Reactors: Historical Review and Future Research Needs, *Engineering*, 2(1), 103–111, 2016.
2. B. R. Sehgal, *Nuclear safety in light water reactors: Severe accident phenomenology*, 1st ed, Academic Press, 48 - 49 and 146 - 152, 2012.
3. H Esmaili, M Khatib-Rahbar, Analysis of in-vessel retention and ex-vessel fuel coolant interaction for AP1000, Energy Research, Inc., Rockville (2004 Aug) NUREG/CR-6849, 2004.
4. Innovative Systems Software, RELAP/SCDAPSIM/MOD3.x User Reference Manual, Volume I: Advanced Fluid Systems Thermal Hydraulics Analysis, Volume II: LWR Fuel Assembly, Core, and Plenum Structure Analysis Under Normal and Accident Conditions, Volume III: Reactor Systems Modeling Options - Reactor Kinetics, 2019.
5. J. L. Rempe, K. Y. Suh, F. B. Cheung, S. B. Kim, In-Vessel Retention Strategy for High Power Reactors, Final Report, INEEL/EXT-04-02561, Idaho National Engineering and Environmental Laboratory, 2005.
6. T.G. Theofanous, On proper formulation of safety goals and assessment of safety margins for rare and high-consequence hazards, *Reliability Engineering & System Safety* 54 (1996) 243-257, 1996.
7. P. Kudinov, S. Galushin, S Yakush, W. Villanueva, V.-A Phung, D. Grishchenko, N T. Dinh, A framework for assessment of severe accident management effectiveness in Nordic BWR plants, PSAM 12; 2014 June; Hawaii (USA).
8. [19] B. S. Kim, K. I. Ahn, C. H. Sohn, Computational Study of the Mixed Cooling Effects on the In-Vessel Retention of a Molten Pool in a Nuclear reactor, *KSME International Journal* 18 (2004) 990-1001, 2004.
9. S. M. Cho, S. J. Oh, A. Diab, Analysis of the in-vessel phase of SAM strategy for a Korean 1000 MWe PWR, *Journal of Nuclear Science and Technology*, 2018.
10. R. J. Park, S.-B. Kim, K. Y. Suh, J. Rempe, Detailed Analysis of Late-Phase Core-Melt Progression for the Evaluation of In-Vessel Corium Retention, *Nuclear Technology* 156 (2006) 270-281, 2006.
11. S. Yakush, P. Kudinov, W. Villanueva and S. Basso, In-Vessel debris bed coolability and its influence on the vessel failure, NURETH-15, Pisa, 2013.
12. A. Goronovski, W. Villanueva, P. Kudinov and T. Chi-Thanh, Effect of Corium Non-Homogeneity on Nordic BWR Vessel Failure Mode and Timing, ICAPP-2015, 2015.
13. S. Yakush, N. Lubchenko and P. Kudinov, Risk and uncertainty quantification in debris bed coolability, NURETH, 2013.
14. D. Magallon, A. Mailliat, J.-M. Seiler, K. Atkhen, H. Sjövall, S. Dickinson, J. Jakab, L. Meyer, M. Buerger, K. Trambauer, L. Fickert, B. Raj Sehgal, Z. Hozer, J. Bagues, F. Martin-Fuentes, R. Zeyen, A. Annunziato, M. El-Shanawany, S. Guentay, C. Tinkler, B. Turland, L.E. Herranz Puebla, European expert network for the reduction of uncertainties in severe accident safety issues (EURSAFE), *Nuclear Engineering and Design* 235 (2005) 309–346, 2005.
15. W. Klein-Heßling, M. Sonnenkalb, D. Jacquemain, B. Clément, E. Raimond, H. Dimmelmeier, G. Azarian, G. Ducros, C. Journeau, L. E. Herranz Puebla, A. Schummg, A. Miassoedov, I. Kljenak, G. Pascal, S. Bechta, S. Güntay, M.K. Koch, I. Ivanov, A. Auvinen, I. Lindholm, Conclusions on Severe Accident Research Priorities. *Annals of Nuclear Energy*, *Annals of Nuclear Energy* 74 (2014) 4 11, 2014.
16. R. T. Tregoning, J. A. Apps, W. Chen, C. H. Delegard, R. Litman, D. D. MacDonald, Phenomena Identification and Ranking Table Evaluation of Chemical Effects Associated with Generic Safety Issue 191, NUREG-1918, 2009.
17. N. Sakai, H. Horie, H. Yanagisawa, T. Fujii, S. Mizokami, K. Okamoto, Validatio of MAAP model enhancement for Fukushima Dai-ichi accident analysis with Phenomena Identification and Ranking Table (PIRT), *Journal of Nuclear Science and Technology*, 51:7-8 (2014) 951-963, 2014.
18. M. Khatib-Rahbar, E. Cazzoli, M. Lee, H. Nourbakhsh, R. Davis and E. Schmidt, A Probabilistic Approach to Quantifying Uncertainties in the Progression of Severe Accidents, *Nuclear Science & Engineering* 102 (1989) 219-259, 1989.

THANK YOU

This research was supported by the 2020 Research Fund of the KEPCO International Nuclear Graduate School (KINGS), Republic of Korea.