

Reactor System Technology 1C

Design to Prevent Interference with Platforms for Vertical Pippings in Research Reactor Pools

• • • •
Hwanho Lee

Kijang Research Reactor Design and Construction Project, KAERI

CONTENTS



01

Introduction

02

Methods and Results

03

Conclusions

04

Acknowledgements & References

01 Introduction

01 Introduction

» Piping and platform in the pools

- The Kijang research reactor pools have **limited space** for radioisotope production, neutron transmutation doping, and fast neutron flux utilization.
- In particular, previous designs required design change **to avoid interference between piping and platform in the pools.**
- The outline of the piping that falls down after passing through the pool penetration **shall not interfere with the pool platform.**
- In this study, the distance between the pool liner and the pipe outline is calculated, and the design modification ensures that **the piping with a nominal diameter of 2-1/2" or less does not interfere with the pool platform.**


02

Methods and Results

02 Methods and Results

» Modified projection type penetration [1] and piping

Thickened plate of pool liner




- Originally, the penetration in the pool was a **projection type**.

P = projection length, mm

H = head plate thickness, mm

02 Methods and Results

» Modified non-projection type penetration [1] and piping [2]



- This figure shows modified pool liner penetration section and piping (non-projection type).

L = pipe length from head plate to elbow, mm

A = elbow curvature, mm

D_o = outside diameter of pipe, mm

T = total length from pool liner to pipe outline, mm

02 Methods and Results

» Non-projection type penetration

- To prevent interference with the pool platforms, **non-projection type penetrations** were applied for vertical pipings with a nominal diameter of 2-1/2" or less.
- The distance between the pool liner and the pipe outline (T) is reduced by the length of the previous projection (P), and the head plate of the pipe is welded directly to the embedded plate of the pool liner.
- Table I shows the calculated results of total length (T) with long radius elbows of 2 and 2-1/2" for non-projection type penetration.

Table I: Total Length with Long Radius Elbow

| NPS, inch | H, mm | A (LR), mm | $\frac{1}{2}D_o$, mm | T, mm |
|-----------|-------|------------|-----------------------|-----------|
| 2 | 9.5 | 76.2 | 30.2 | 115.9 + L |
| 2-1/2 | | 95.3 | 36.5 | 141.3 + L |

NPS: Nominal Pipe Size

LR: Long Radius (A = 1.5 NPS)

02 Methods and Results

» Non-projection type penetration

- For pipings of 2" or less with non-projection type penetration, there are no interference with the pool platforms. **However, 2-1/2" pipings require additional design change.**

02 Methods and Results

» Short radius elbow

- Considering welding for 2-1/2" pipings including variable pipe length (L), it is not easy to avoid interference with the pool platforms.
- Because the total length (T) decreases as the elbow curvature (A) decreases, the elbows are changed from long radius to short radius for 2-1/2" pipings. Table II shows the calculated result of total length (T) with short radius elbow of 2-1/2".

Table II: Total Length with Short Radius Elbow

| NPS, inch | H, mm | A (SR), mm | $\frac{1}{2}D_o$, mm | T, mm |
|--------------|----------|---------------|--------------------------|-----------|
| 2-1/2 | 9.5 | 73.0 | 36.5 | 119.0 + L |

SR: Short Radius (A = 1.0 NPS)

- For pipings of 2-1/2" with short radius elbow, there are no interference with the pool platforms.

03 Conclusions

03 Conclusions

- » In this study, the total lengths from the pool liner to the pipe outline are calculated for some cases, and no interference was made through design modifications.
- » The design changes include the application of non-projection type penetration and short radius elbow.
- » This method can be expanded to other types of penetration and sizes of piping and it will be useful in the efficient use of limited space.

04

Acknowledgements & References

04 Acknowledgements & References

» Acknowledgements

- This project is supported by the National Research Foundation of Korea (NRF) grant funded by the Government of Korea (MSIT: Ministry of Science and ICT) (No. 2020M2C1A1061043).

» References

- [1] ASME Boiler and Pressure Vessel Code, Section III, Subsection NF, Supports, American Society of Mechanical Engineers, 2004.
- [2] ASME B16.9, Factory-made Wrought Buttwelding Fittings, American Society of Mechanical Engineers, 2001.

THANK YOU