

KNS Autumn Meeting,

# A Conceptual Study of a system combines FS-MSR and ESS

---

**Jaejin Choi**

*Department of Nuclear Quantum Engineering  
Korea Advanced Institute of Science and Technology*

**October 21 , 2021**

# Contents

---

- ❖ Topic introduction
- ❖ Study background
- ❖ RVACS test method & results
- ❖ Future work
- ❖ Conclusion

# Topic Introduction

---

- Development of clean energy system technology
  - Without pollutant & supply of electricity stays constant the day
  - Distributed power → high inherent safety
  
- **Fast Spectrum Molten Salt Reactor (FS-MSR) + Liquid Air Energy Storage System (LAES)**
  - FS-MSR is new generation reactor which have long life time(50years) without online-refueling
  - Target FS-MSR is 100MW<sub>th</sub> power
  - LAES has large energy storage capacity
  - LAES collects carbon dioxide and fine dust during energy conversion and supplies clean air.

# Topic Introduction

- Passive residual heat removal system (PRHRS) for Fast-Spectrum Molten Salt Reactor (FS-MSR).
  - RVACS: Reactor Vessel Auxiliary Cooling System
  - Passive safety system which air cooled by natural circulation
  - Prevent the core temperature increasing after reactor shutdown.
- Find out the feasibility of RVACS
  - Simple evaluated by MATLAB calculation
  - Optimizing design parameters for  $100\text{MW}_{\text{th}}$  FS-MSR




Fig1. RVACS System

# Background Study -core

- Fuel efficiency : online-refueling problem
- Low waste production: fast neutron < thermal neutron




Fig2. U-238 reaction in Fast reactor

- Chloride based salt
  - Moderator effect: Fluoride based salt > Chloride based salt
  - Viscosity: Fluoride based salt > Chloride based salt → high power density by pump

Molten salt	Viscosity (kg/m*s)
LiF-NaF-KF (46.5-11.5-42)	6.3e-3
LiF-NaF-ZrF <sub>4</sub> (26-37-37)	16.6e-3
LiCl-KCl (59.5-40.5)	1.8e-3
NaCl-KCl-MgCl <sub>2</sub> (30-20-50)	2.1e-3

# Background Study -core

## Target reactor core design parameters

- Eutectic point : mole fraction 54%
- Fuel salt: 46KCl-54UCl<sub>3</sub>
- Cl enrichment: 99 a/o
- U235 enrichment: 19.75 w/o
- Core temperature : 650 °C
- Core diameter(height): 218cm
- Initial heavy metal inventory: 35,576kg
- Initial excess reactivity: 6608 ± 15 pcm

- Helium bubbling → remove noble metal
- Off-gas system → gaseous fission products





Fig2. Reactor core design

# Background Study -ESS

## ■ Electricity consumption rate by hour in July

- 34.7% higher at noon to midnight → need a energy storage



Fig3. power consumption(July, 2020)

## ■ ESS type: Liquid air energy storage (LAES)

- LAES should have a capacity to store at least 14.8% of power generation
- 4.44MWe/53.28MWh capacity energy storage system is needed.

# Background Study -ESS

- A supercritical CO<sub>2</sub> power conversion system applied
  - High temperature Brayton cycle, high efficiency than rankine cycle ( < 5%)
  - Carbon dioxide capture mechanism
  - High density fluid make system simplify
  - Propose system optimum turbomachinery speed is 10,000RPM, 40cm, type is radial multi stage.
  
- Thermal energy storage (TES) to store heat transferred without temperature decrease
  - Control the reactivity (temperature control)
  - Hot & Cold insulated tank
  - ex) Crescent Dunes (USA), Andasol (Spain), Aurora (Australi)

TM Feature	Power (MWe)						
	0.3	1.0	3.0	10	30	100	300
TM Speed/Size	75,000 / 5 cm		30,000 / 14 cm		10,000 / 40cm		3600 / 1.2 m
Turbine type	Single stage		Radial		multi stage		
					single stage		Axial multi stage
	Single stage		Radial		multi stage		
Bearings	Gas Foil			Hydrodynamic oil			
				Magnetic		Hydrostatic	
Seals	Adv labyrinth			Dry lift off			
Freq/alternator	Permanent Magnet			Wound, Synchronous			
				Gearbox, Synchronous			
Shaft Configuration	Dual/Multiple			Single Shaft			

Fig4. sCO<sub>2</sub> optimum



# Background Study -ESS




Fig5. Combines System

# Background Study -RVACS

- There are no previous study about RVACS application for FS-MSR.
  - Direct reactor auxiliary cooling system(DRACS), Primary reactor auxiliary cooling system(PRACS) exists
  - The RVACS heat removal capacity was investigated for similar types of reactor
  - The existing models were compared, and satisfactory heat removal criteria were determined

- IRACS fails completely, RVACS is able to remove shutdown heat as a fully passive system of air convection.




Fig6. Heat removal path

# Background Study - RVACS

- PRISM reactor has RVACS that heat removal capacity was 0.7% of full power using the air. Also, SAFR reactor has 0.6% heat removal capacity and Phenix reactor has 0.7%.
- These reactors have different characteristics from FS-MSR, because neutron leakage rate and temperature distribution are totally different. However these reactor was designed heat removal capacity is about 0.6~0.7 % of full power. Therefore, it is applicable if the target heat removal of FS-MSR satisfies under 0.6%

Reactor	Power (MWth)	Coolant	RVACS method	Heat remove (% full power)	mechanism
PRISM	840	Sodium	RVACS with air	0.7	Natural
SAFR	900	Sodium	RVACS with air	0.6	Natural
IMSR	400	Molten Salt	RVACS with Nitrogen	unknown	Natural
Phenix	840	Sodium	RVACS with water	0.7	Forced
CLEAR-I	45	Lead	RVACS with air tubes	0.2	Natural

Table3. RVACS application reactor features <sup>[3]</sup>

# Research Question

---

- Find out the feasibility of Reactor Vessel Auxiliary Cooling System (RVACS)
  - The exist RVACS's target feature ability is 0.2 ~ 0.7%
  - RVACS target for FS-MSR is remove 0.6% of full power ( $600\text{kW}_{\text{th}}$ )
- Optimizing design parameters for our target reactor
  - CV outer wall temperature affects heat removal ability
  - Total heat removal capacity
  - Stack height
  - Air path thickness

# RVACS test methods

- Using MATLAB code calculation (natural circulation)
  - Simplified geometry (overflow x)
  - Considering : pressure drop, Convection & Radiation heat transfer
  - Changing values: Air patch thickness, mass flow rate

Design parameter	value
Air inlet Temperature	50 °C
CV temperature	600 °C
CV diameter	3 m
Air path thickness	3 – 7 cm
Air mass flow rate	1 – 3 kg/s

Table1. RVACS design parameter




Fig7. RVACS cross section




Fig8. RVACS side view drawing

# RVACS test results

- Target of heat removal capacity is 0.6% of the full power.
  - 100MW<sub>th</sub> reactor using, so 600kW<sub>th</sub> decay heat removal capacity design
  - Case3 is optimization design (stack height is acceptable( <15m) and high heat removal)




Fig9. Heat removal rate




Fig10. Stack height

Case	Case 1	Case 2	Case 3	Case 4
Air path thickness	3cm	3.5cm	4cm	4.5cm
Air mass flow rate	2kg/s	2.5kg/s	3kg/s	3kg/s
Stack height	12.4m	13.2m	14.0m	10.5m
Heat remove	552.0kW	588.0kW	611.0kW	560.0kW
Air outlet temperature	317.3°C	278.5°C	248.4°C	232.1°C
Air heat transfer coefficient	27.6W/m <sup>2</sup> K	27.7W/m <sup>2</sup> K	27.6W/m <sup>2</sup> K	24.4W/m <sup>2</sup> K

Table2. Code calculation results

# RVACS test results

- The percent of convection decay heat removal is 55%.
- If containment vessel wall temperature increase
  - Heat removal capacity is increase.
  - Necessary stack height is decrease.




Fig11. The ratio of convection to radiation heat removal




Fig12. Heat removal




Fig13. Stack height

# RVACS test results

- Evaluate the applicability to higher reactor power(200, 300MW<sub>th</sub>)
  - Air path thickness is 4 cm fixed
  - CV diameter, stack height are variables
- Increase CV diameter is essential to improve RVACS performance




Fig14. Stack height (200MWth)




Fig15. Stack height (300MWth)



# Limitation of Study & Future work

---

- This is preliminary conceptual study about RVACS application for FS-MSR
  - There many assumptions (especially concrete silo temperature was unapplied)
  - It is difficult to obtain the CV outer wall temperature distribution (viscosity, heat conductivity coefficient)
  - The placement of Internal Heat Exchanger(IHX) and internal structure of reactor vessel also need to considered
  
- Ar41 is produced from irradiation of air due to neutron leakage
  - Looking for a solution to prevent air pollution
  - Closed circuit geometry (valve or damper)
  - Compare heat loss in normal operation and mechanical operation

# Conclusion

---

- **Combination system**
  - Fast spectrum Molten salt reactor
  - TES + LAES + sCO<sub>2</sub> power conversion
  - RVACS, residual heat removal
- **The feasibility of RVACS evaluation result is enough to decay heat removal after 100MW<sub>th</sub> reactor shutdown.**
- **Optimized design for 611kW<sub>th</sub> decay heat removal using RVACS**
  - Air path thickness is 4cm, air mass flow rate is 3kg/s
  - The required stack height is 14m
  - Air heat transfer coefficient is 27.6 W/m<sup>2</sup> K

# References

---

General Electric, PRISM, Preliminary Safety Information Document, prepared for U.S Department of Energy Under Contract No.DE-AC03085NE37937, December. 1987. Volume 2

CHENG, Lap-Yan. *Phenomena Important in Liquid Metal Reactor Simulations*. Brookhaven National Lab.(BNL), Upton, NY (United States), 2018.

LISOWSKI, Darius, et al. Technical Letter Report: An Overview of Non-LWR Vessel Cooling Systems for Passive Decay Heat Removal. 2021.

BOARDMAN, C. E.; HUNSBEDT, A. *Performance of ALMR passive decay heat removal system*. 1991.

Eoh, Jae-Hyuk, et al. "Feasibility study of a passive DHR system with heat transfer enhancement mechanism in a lead-cooled fast reactor." *Nuclear technology* 160.2 (2007): 216-232.

HUNSBEDT, A. *Experiments and analyses in support of the US ALMR thermal-hydraulic design*. 1993.

**Thank you**

---