


DHRS Performance Test Results of STELLA-2 & Comparison with MARS-LMR Analysis

(LOF Transient with 1 PDHRS and 1 ADHRS)



Jewhan LEE, Yong-Bum LEE, Byeongyeon KIM, Jung YOON

May 20, 2022



CONTENTS



01 Introduction

02 Test Condition

03 Comparison between Experiment & Code

04 Conclusion

Introduction

» STELLA Program

► Purpose :


- To demonstrate safety performance of DHRS coupled with primary system

► Significance :

- State-of-art large-scale sodium facility
- Focus on transient behavior

» Program Progress

- Phase I (separate effect test) completed in 2017
- Phase II (integral effect test) on-going
 - Construction finished in 2020




Introduction

» STELLA-2 Capability

► Major transients of concern


- **Loss of Heat Sink (LOHS)**
i.e. Loss of F/W and SG failure
- **Loss of Flow (LOF)**
i.e. PHTS pump failure (single or double)
- **PHTS pump discharge pipe break**
- **Total loss of DHR**
(simulation of in-vessel retention
with ex-vessel cooling)



STELLA-2 Design Features

» System Layout

- ▶ Dynamic & Independent Loops
 - 1 vessel & 8 loops
 - 5 different types of heat exchanger
- ▶ Design Temp & Press
 - 600°C & 5 bars
- ▶ Scale
 - 1/5 (length), 1/125 (volume)
- ▶ Dimension
 - 18 X 15 X 30 (m)
- ▶ Net Sodium Inventory
 - 15 tons
- ▶ Power
 - Total : ~3.0 MW



STELLA-2 Design Features





Test Condition

» Target Transient


- ▶ LOF with 1 ADHRS and 1 PDHRS working

» Steady-state Point


- ▶ Heat balance of normal operation




Core Temp




IHX Temp




UHX Temp



IHX heat transfer



Primary Flow



Intermediate Flow

Test Condition


» Event Sequence

- ▶ PHTS pump 1 & 2 stop
 - 1.25 kg/s → 0.0 kg/s
- ▶ IHTS pump 1 & 2 stop
 - 0.92 kg/s → 0.0 kg/s
- ▶ UHX 1 & 2 stop
 - Blower off
- ▶ Reactor trip
 - Starts to follow decay heat curve
- ▶ DHRS starts to operate
 - 100% 1 ADHRS (FHX) + 100% 1 PDHRS (AHX) working

Comparison btw Experiment & Code

» Primary Flowrate

- ▶ Natural circulation flowrate comparison
- ▶ Difference 1
 - Code results are smaller by 35 ~ 53%
 - Measurement uncertainties
 - Unexpected heat loss
- ▶ Difference 2
 - PSLS-1 & PSLS-2 values are switched
 - Asymmetrical flow distribution




Primary Flowrate Comparison

Comparison btw Experiment & Code

» Core In/Out Temperature Trend

- ▶ Long-term cooling capability is verified
- ▶ Difference
 - Code results of core ΔT is 1.6 ~2.8 larger
 - Unexpected heat loss




Core Temperature Comparison

Comparison btw Experiment & Code

» IHX Shell-side Temperature Trend

- ▶ Large difference in trend
- ▶ Difference 1
 - Shell inlet temp is lower than core outlet
→ Unexpected heat loss
- ▶ Difference 2
 - ΔT is much smaller
→ No flowrate in code, Yes flowrate in real
※ No credit for safety analysis of reactor



IHX Temperature Comparison

Comparison btw Experiment & Code


» Heat Removal through AHX & FHX

▶ Smaller heat removal rate but similar trend


▶ Difference

- Smaller ΔT & smaller flowrate


→ Less heat for removal due to heat loss




Air Temperature Comparison




AHX Sodium Temp



AHX Sodium Flow



FHX Sodium Temp



FHX Sodium Flow

Conclusion

- » **LOF transient experiment successfully conducted**
 - ▶ 1 ADHRS and 1 PDHRS working condition was tested
 - ▶ Experiment results were compared with code calculation

- » **Flowmeter problem was found and will be re-calibrated**
 - ▶ Over-measurement will need to be fixed

- » **Unexpected heat loss was identified**
 - ▶ It will be addressed with further study

Thank you