

The results include proposed lists of IEs for RITM-200N full power operation. The integral primary

boundary removes loop-piping large-break LOCA; accordingly, the LOCA family is limited to vessel/penetration-credible small- and medium-break cases, typical for large-scale reactors, with explicit inclusion of a functional-LOCA mode arising from a Gas Pressure Control System (GPCS) relief valve stuck open due to its coupling with Hydroaccumulators (HAs). Primary-to-secondary pathways are differentiated as conventional Steam Generator Tube Rupture (SGTR) and a cassette header rupture (distinct failure geometry for cassette steam generators). An integral-unique primary-to-intermediate heat-exchanger tube rupture is carried to represent a primary-to-intermediate cooling circuit leakage path with no direct analogue in loop-type plants, as it propagates into the closed intermediate cooling circuit and impacts the safety heat-sink chain.

Table 1: Proposed list of PRA-based IEs for RITM-200N for full power operation

Group	IE
1. Loss of Coolant (LOCA)	#LLOCA - Large LOCA
	SLOCA - Small LOCA
	MLOCA - Medium LOCA
	*GPCS pressure relief valve stuck open
	SGTR - Steam Generator Tube Rupture
	*SG cassette header rupture
	*Primary - Intermediate Heat Exchanger (HX) tube rupture
	ISLOCA - Interfacing System LOCA
2. Secondary breaks & major transients	MSLB - Main Steam Line Break (inside/outside; isolable/not isolable)
	FWLB - Feedwater Line Break (inside/outside)
	LOFW - Loss of Feedwater
	LOCV/loss of heat sink - Loss of Condenser Vacuum/heat sink
	GTRN - General Transients
3. Reactivity/protection	ATWS - Anticipated Transients without SCRAM
4. Electrical power	LOOP - Loss of Offsite Power (short-term)
	LOOP - Loss of Offsite Power (long-term)
	SBO Station Blackout
	Loss of DC bus
	Loss of safety-class AC bus
5. Heat sink chain/support	Partial loss of Intermediate Cooling Circuit (ICC)
	Total loss of Intermediate Cooling Circuit (ICC)
	Partial loss of Technical Water System (TWS)

	Total loss of Technical Water System (TWS)
	LOIA - Loss of Instrument Air (as applicable)

The proposed IE sets for RITM-200N keep the familiar PWR logic but recast it around an integral vessel. At full power, loop-piping large breaks drop out, marked as #LLOCA as an excluded due to the design IE; the LOCA family is limited to small and medium primary losses credible on an integral boundary. Design-specific IEs are marked with “*”, as *GPCS pressure relief valve is a functional LOCA on an integral vessel. In RITM-200N (Fig.1) GPCS, unlike classical Pressurizer in VVER-1000 or APR1400, ties into Hydroaccumulators, that will inject automatically when Reactor Coolant System pressure drops and crosses their setpoint. Primary to secondary paths are carried explicitly as SGTR and *SG cassette header rupture. *Primary to Intermediate HX tube rupture (CDPS-HX tube rupture) creates primary-to-ICC leakage, degrading Intermediate loop and safety paths relying on it. PWRs transfer core heat only across the SG tubes (primary-to-secondary), in RITM-200N, by contrast, ICC is a closed safety-related circuit, that takes heat from safety Cooldown and purification System (CDPS) HXs and transfers it to TWS, hence the IE related is considered separately. An Interfacing System LOCA, or primary leak outside containment is retained. Secondary side initiators follow established practice: MSLB variants, FWLB, LOFW, LOCV or heat sink, and GTRN envelope. One reactivity outlier is kept as a separate initiator, ATWS. Electrical initiators include short- and long-term LOOP, SBO, and loss of a vital DC or safety AC bus. Support system initiators reflect the heat sink chain of an integral plant. Degradation or failure of ICC is crucial as it that serves CDPS. TWS loss implies condenser heat sink loss, ICC sink loss, Diesel Generators run time might become limited (if depend on TWS, not specified in the design information available). LOIA is included only if safety significant pneumatic actuation is credited.

3. Conclusions

This study proposes mode-specific IEs for an integral SMR, derived from a Design-based-to-PRA mapping benchmarked against APR1400 and VVER-1000 practice. The set includes design specific items that reflect the integral vessel, internal interfaces, and the plant’s heat sink chain. The result is a usable foundation for PRA work in Uzbekistan: define plant specific success criteria, build event and fault trees, set data needs, and proceed to quantification and review.

ACKNOWLEDGMENTS

This research was supported by 2025 Research Fund of the KEPKO International Nuclear Graduate School (KINGS), the Republic of Korea.

REFERENCES

- [1] Rosenergoatom Concern JSC, Kalinin Unit 1 VVER-1000 Level 1 PRA Report, Plant-specific PRA Report, Vol. 1, No. 1, pp. 1–35, 2006.
- [2] Korea & Nuclear Power Co., Ltd., APR1400 Design Control Document, Tier 2, Chapter 19: Probabilistic risk assessment, U.S. NRC Docket Files, Vol. Tier 2, No. 19, pp. 15.0-43 – 15.0-45, 15.1-1 – 15.1-31, 2019.
- [3] Federal Environmental, Industrial and Nuclear Supervision Service of Russia (Rostekhnadzor), Requirements for the content of safety analysis reports for nuclear power plant units with VVER reactors (NP-006-16), Regulatory Standard, Vol. NP-006-16, No. 2017, pp. 268-270, 2017.
- [4] Korea Hydro & Nuclear Power Co., Ltd., APR1400 Design Control Document, Tier 2, Chapter 15: Transient and accident analyses, U.S. NRC Docket Files, Vol. Tier 2, No. 15, pp. 19.1-5 – 19.1-52, 2019.
- [5] International Atomic Energy Agency, Design Features to Achieve Defence in Depth in Small and Medium Sized Reactors, IAEA Nuclear Energy Series No. NP-T-2.2, Vienna, pp. 22-24, 92-94, 2009.