

Evaluation of Cs-137 Release Frequency Exceeding 100 TBq using MPAS Level 2 PSA Model and MELCOR

FNC Technology.
Gyeongyeol Kim, Hyun-bin Chang, MyeongKwan Seo
Suwon Lee, Jung Hyun Ryu

2026. 05



주미래와도전
FNC Technology Co., Ltd.

CONTENTS

- 1 • Introduction
- 2 • Methodology and Result
- 3 • Conclusions and Further Studies

1

Introduction

1 Introduction

Background

➤ Background of Cs-137 Release Frequency Exceeding 100TBq

■ NSSC Notice No. 2026-1, Article 9

- The regulatory body shall verify whether the PSA results submitted by the licensee satisfy the following criteria
 - The risks of early fatality and latent cancer shall each be less than 0.1% of the total risk or meet equivalent performance goals (Target 1)
 - The total frequency of accidents resulting in Cs-137 release exceeding 100 TBq shall be less than 1.0×10^{-6} per year (Target 2)

■ Target 1

■ NRC Safety Goal Policy Statement (QHO)

- QHO(Quantitative Health Objectives): Early fatality risk $\leq 0.1\%$, Latent cancer fatality risk $\leq 0.1\%$

■ NUREG-1150

- Level 1, 2, 3 PSA -> Dose assessment, Quantification of Early fatality risk and Latent Cancer fatality risk

■ [NRC Regulatory Guide 1.174]

- CDF $\leq 1.0E-4$, LERF $\leq 1.0E-5$

■ Target 2

■ Derived from the LERF concept of Target 1

- Conservatively increased by a factor of 10 to account for uncertainty ($1.0E-5 \rightarrow 1.0E-6$)

■ Evaluated through Level 2 PSA Source Term Analysis

1 Introduction

Objective

➤ Objective of Multi-Purpose Probabilistic Analysis of Safety(MPAS) PSA


- To verify the validity and adequacy of PSA results submitted by the licensee for both Target 1 and Target 2

- Verification Method for Target 1

- CDF: Derived from MPAS Level 1 PSA model
- LERF: Derived from MPAS Level 2 PSA model

- Verification Method for Target 2

- Cs-137 Release Frequency Exceeding 100TBq: Derived from MPAS Level 2 PSA model & Source Term Analysis
- Currently, no prior experience exists for regulatory Source Term Analysis

 Independent Regulatory Verification of the Licensee's Cs-137 Release Frequency Exceeding 100 TBq

1 Introduction

Tools for Source Term Analysis

- APR1400 MPAS Level 2 PSA Model
 - Incorporation of New Strategies Included in the Accident Management Program (MACST, SAMG)
 - Applying state-of-arts Level 2 PSA Study results
 - RCSFAIL DET: RASP Handbook V5(NUREG-2195) & NUREG/CR-6109
 - DET updated based on severe accident progression analysis

- MELCOR Code
 - Severe Accident Thermal-Hydraulic and Source Term Analysis code
 - Source Term Behavior Simulation and Release Quantification for each Accident Sequence

- Analysis Framework
 - Selection of accident sequences for analysis
 - Source Term Analysis using MELCOR
 - Quantification of the Cs-137 Release Frequency Exceeding 100 TBq
 - Comparison with the licensee's analysis results

2


Methodology and Result

2 Methodology and Result



2.1 Selection of Accident Sequences for Analysis

➤ APR1400 MPAS Level 2 PSA Model Structure



Identification of Accident Sequences and Release Pathways Based on the MPAS Level 2 PSA Model

2 Methodology and Result

2.1 Selection of Accident Sequences for Analysis


➤ Analysis of the APR1400 MPAS Level 2 PSA Model Quantification Results (1/2)

■ PDSET Quantification

■ Tools: AIMS, Ftrex

■ Output: Minimal CutSets (MCS) of Plant Damage State(PDS) Frequency

- [Group By Summation]: Importance Analysis of Accident Sequences based on PDS frequency is possible



The screenshot shows the AIMS software interface for the file 'APR1400-INT-CDF'. The 'Group By' tab is active, and the 'Sum' icon (Σ) is highlighted with a red circle and a red arrow pointing to it from the text 'Group By Summation'. The main table displays the following data:

Level	Group	Pattern	Style	IE	Value	Seq	Value
1	IE	%*	Event	1	%IDV11A-LOCA	#GIE-DVI-LOCA-02!	
2	Seq	#*	Event	2		#GIE-DVI-LOCA-03!	
				3		#GIE-DVI-LOCA-04!	
				4		#GIE-DVI-LOCA-05!	
				5		#GIE-DVI-LOCA-07!	
				6		#GIE-DVI-LOCA-08!	
				7		#GIE-DVI-LOCA-09!	
				8		#GIE-DVI-LOCA-13!	
				9		#GIE-DVI-LOCA-14!	

2 Methodology and Result



2.1 Selection of Accident Sequences for Analysis

➤ Analysis of the APR1400 MPAS Level 2 PSA Model Quantification Results (2/2)

Level 2 (PDSL - CET/DET – STCLD) Quantification

Tool: AIMS-L2

Outputs: PDS / CET / STC Frequency, PDS - CET Sequence(with STC) Mapping Table

[Save Logic as FTP]

- [PDSET Sequence] – [PDS No.] Mapping
- [PDS No.] – [CET Sequence] – [STC] Mapping
- AIMS [Group By Summation] : Importance Analysis across [PDSET Sequence] – [PDS No.] – [CET Sequence] – [STC]

	CET	STC	PDS-1	PDS-2	PDS-3	PDS-4	PDS-5	PDS-6	PDS-7	PDS-8
1	1		0	0	0	0	0	0	0	0
2	2		7.418253e-2	7.425679e-2	0	0	0	0	0	0
3	11		7.425679e-5	7.433112e-5	0	0	0	0	0	0
4	5		0	0	0	0	0	0	0	0
5	5		0	0	0	0	0	0	0	0
6	8		0	0	0	0	0	0	0	0
7	8		0	0	0	0	0	0	0	0
8	11		0	0	0	0	0	0	0	0
9	5		0	0	0	0	0	0	0	0
10	8		0	0	0	0	0	0	0	0
11	2		0	0	0	0	7.418253e-2	7.425679e-2	0	0
12	11		0	0	0	0	7.425679e-5	7.433112e-5	0	0
13	6		0	0	0	0	0	0	0	0
14	6		0	0	0	0	0	0	0	0
15	9		0	0	0	0	0	0	0	0
16	9		0	0	0	0	0	0	0	0
17	11		0	0	0	0	0	0	0	0
18	7		0	0	0	0	0	0	0	0
19	10		0	0	0	0	0	0	0	0
20	2		3.251290e-7	3.254545e-7	3.251290e-4	3.254545e-4	3.251290e-7	3.254545e-7	3.251290e-4	3.254545e-4
21	11		3.254545e-10	3.257803e-10	3.254545e-7	3.257803e-7	3.254545e-10	3.257803e-10	3.254545e-7	3.257803e-7
22	6		1.132599e-5	1.133733e-5	1.132599e-2	1.133733e-2	1.132599e-5	1.133733e-5	1.132599e-2	1.133733e-2
23	6		1.133733e-8	1.134868e-8	1.133733e-5	1.134868e-5	1.133733e-8	1.134868e-8	1.133733e-5	1.134868e-5
24	9		6.260566e-5	6.266833e-5	6.260566e-2	6.266833e-2	6.260566e-5	6.266833e-5	6.260566e-2	6.266833e-2
25	9		6.266833e-8	6.273106e-8	6.266833e-5	6.273106e-5	6.266833e-8	6.273106e-8	6.266833e-5	6.273106e-5

id	PDSET Seq.	PDS No.	CET Seq.	STC		
	Seq	Value	PDS_CET	Value	STC	Value
1	#GIE-ATWS-070		CET_F_P49	C001	#STC-01	
2			CET_F_P49	C002	#STC-02	
3			CET_F_P49	C029	#STC-02	
4	#GIE-ATWS-071		CET_F_P53	C001	#STC-01	
5			CET_F_P53	C011	#STC-02	
6	#GIE-ATWS-075		CET_F_P50	C001	#STC-01	
7			CET_F_P50	C002	#STC-02	
8	#GIE-ATWS-076		CET_F_P54	C001	#STC-01	
9	#GIE-ATWS-080		CET_F_P57	C002	#STC-02	
10			CET_F_P57	C029	#STC-02	
11			CET_F_P57	C084	#STC-04	
12	#GIE-ATWS-081		CET_F_P61	C011	#STC-02	
13	#GIE-ATWS-082		CET_F_P61	C011	#STC-02	
14			CET_F_P61	C038	#STC-02	
15			CET_F_P61	C084	#STC-04	

2 Methodology and Result

2.1 Selection of Accident Sequences for Analysis

➤ Classification of STCs by Containment Damage State

Containment Damage State	NOCF	ECF	LCF	BMT	CFBRB	NOTISO	BYPASS
STC No.	1 ~ 2	3 ~ 4	5 ~ 10	11	12	13~14	15 ~ 18

➤ Procedure for Selecting Representative Accident Sequences

1) Selection of Accident Sequences by Containment Damage State

- High-impact, high-frequency sequences selected

2) Review of Accident Progression

- Inclusion of key severe accident phenomena confirmed

3) Definition of Containment Failure Conditions

- Containment failure pressure, timing, and conditions defined

➤ Result of Selecting Representative Accident Sequences

Containment Damage State	Representative Accident Sequence		
	PDSET Sequence	STC	Contribution (%)
NOCF	TLOCCW-28	2	40.6
ECF	TLOCCW-34	4	13.9
LCF	TLOCCW-30	9	30.3
BMT	TLOCCW-31	11	26.4
CFBRB	MLOCA-2	12	85.8
NOTISO	SBOS-300	14	6.3
BYPASS	ISLOCA-2	16	0.1

2 Methodology and Result



2.2 Source Term Analysis using MELCOR

- Source Term Analysis using MELCOR
 - Development of MELCOR Input for Representative Sequences
 - Initiating Event conditions
 - Availability of safety-related systems
 - Containment failure conditions by containment damage state
 - Failure pressure
 - Time of failure
 - Failure mode (Leakage or Rupture)
 - Release pathways to the environment

2 Methodology and Result




2.2 Source Term Analysis using MELCOR

➤ NOCF Representative Accident Sequence (TLOCCW-28)

■ Characteristic of Accident Sequence

TLOCCW	RT	SHR	CIS	RDP	CFL	ECSBS	LTCHR
-	O	X	O	O	O	O	O



■ Design leakage release assumed

2 Methodology and Result




2.2 Source Term Analysis using MELCOR

➤ ECF Representative Accident Sequence (TLOCCW-34)

■ Characteristic of Accident Sequence

TLOCCW	RT	SHR	CIS	RDP	CFL	ECSBS	LTCHR
-	O	X	O	X	O	O	O



- Design leakage release assumed
- Containment failure is assumed at the time of reactor vessel failure

2 Methodology and Result




2.2 Source Term Analysis using MELCOR

➤ LCF Representative Accident Sequence (TLOCCW-30)

■ Characteristic of Accident Sequence

TLOCCW	RT	SHR	CIS	RDP	CFL	ECSBS	LTCHR
-	O	X	O	O	O	X	X



■ Design leakage release assumed

■ Containment failure is assumed upon reaching the pressure corresponding to a 5% failure probability on the containment fragility curve

2 Methodology and Result




2.2 Source Term Analysis using MELCOR

➤ BMT Representative Accident Sequence (TLOCCW-31)

■ Characteristic of Accident Sequence

TLOCCW	RT	SHR	CIS	RDP	CFL	ECSBS	LTCHR
-	O	X	O	O	X	O	O



■ Design leakage release assumed

■ Basemat melt-through (BMT) is assumed when the cavity floor erosion reaches a specified depth

2 Methodology and Result




2.2 Source Term Analysis using MELCOR

CFBRB Representative Accident Sequence (MLOCA-2)

Characteristic of Accident Sequence

MLOCA	SIS	HIN	CONSPRAY
-	O	O	X



Design leakage release assumed

Containment failure is assumed upon reaching the pressure corresponding to a 5% failure probability on the containment fragility curve

2 Methodology and Result




2.2 Source Term Analysis using MELCOR

➤ NOTISO Representative Accident Sequence (SBOS-300)

■ Characteristic of Accident Sequence

SBOS	AAC	TD-AFW	RCPSEAL	PMG	PLG	RACL	SHRL	CIS
-	X	O	O	X	X	X	X	X



- Design leakage release assumed
- Failure of containment penetration isolation

2 Methodology and Result




2.2 Source Term Analysis using MELCOR

➤ BYPASS Representative Accident Sequence (ISLOCA-2)

■ Characteristic of Accident Sequence

ISLOCA	HPI
-	X



- Design leakage release assumed
- ISLOCA assumed due to rupture of the shutdown cooling system suction line

2 Methodology and Result

2.3 Quantification of the Cs-137 Release Frequency Exceeding 100 TBq

➤ Calculation of Cs-137 Release by Containment Damage State

- Identification of the initial Source Term inventory in the core
- Calculation of the total release quantity of fission products containing Cs
 - Class 2(CS)
 - Class 16(CSI)
 - Class 17(CSM)
- Derivation of the Cs mass fraction within Cs-containing fission product compounds using molar fractions
 - Class 2(CS)
 - Cs 100%
 - Class 16(CSI)
 - CsI: $M_{Cs} = 132.905 \text{ g/mol}$, $M_I = 126.904 \text{ g/mol}$
 - Cs mass fraction: $M_{Cs} / (M_{Cs} + M_I) = 0.5116$
 - Class 17(CSM)
 - Cs_2MoO_4 : $M_{Cs} = 132.905 \text{ g/mol}$, $M_{Mo} = 95.950 \text{ g/mol}$, $M_O = 15.999 \text{ g/mol}$
 - Cs mass fraction: $2 M_{Cs} / (2 M_{Cs} + M_{Mo} + 4 M_O) = 0.6243$
- Application of the Cs-137 inventory fraction relative to the initial Cs inventory
- Calculation of Cs-137 activity
 - Using the Cs-137 mass (m), molar mass (M), Avogadro's number (N_A), and decay constant (λ)
 - $A = \lambda \frac{m}{M} N_A$

2 Methodology and Result

2.3 Quantification of the Cs-137 Release Frequency Exceeding 100 TBq

➤ Cs-137 Release Calculation Card in MELCOR

```

!           cfname      icfnum      cftype
CF_ID      'Cs_Frac_Envir'      1300      ADD
!           cfscal      cfadcn
CF_SAI      0.00449      0.0
!           icflim
CF_ULB      DEFAULT      0.0      0.0
!           size
CF_ARG      3 In           cfarg      arscal      aradcn
            1 RN1-TYCLT(CS,CTYP-6,RAD)      1.0
            2 RN1-TYCLT(CSI,CTYP-6,RAD)      0.51155600
            3 RN1-TYCLT(CSM,CTYP-6,RAD)      0.6243      !0.73478922 = Cs2Mo, 0.6243 = Cs2MoO4
!
!           cfname      icfnum      cftype
CF_ID      'Cs_mass_Env'      1350      ADD
!           cfscal      cfadcn
CF_SAI      1.0      0.0
!           icflim
CF_ULB      DEFAULT      0.0      0.0
!           size
CF_ARG      3 In           cfarg      arscal      aradcn
            1 RN1-TYCLT(CS,CTYP-6,RAD)      1.0
            2 RN1-TYCLT(CSI,CTYP-6,RAD)      0.51155600
            3 RN1-TYCLT(CSM,CTYP-6,RAD)      0.6243      !0.73478922 = Cs2Mo, 0.6243 = Cs2MoO4

```

2.3 Quantification of the Cs-137 Release Frequency Exceeding 100 TBq

➤ Cs-137 Release Quantity and Frequency of Releases Exceeding 100 TBq

Containment Damage State	Cs-137 Release Quantities (TBq)	Frequency (/yr)	Contribution (%)
NOCF	~10.0	~2.0E-06	44.7
ECF	~100,000.0	~1.0E-08	0.2
LCF	~10,000.0	~2.0E-06	47.0
BMT	~10.0	~1.5E-07	3.5
CFBRB	~10,000.0	~1.5E-07	3.1
NOTISO	~100,000.0	~1.5E-08	0.3
BYPASS	~100,000.0	~5.5E-08	1.2
Release Category			
Cs-137 (> 100 TBq)		~2.5E-06	51.8

2 Methodology and Result

2.4 Comparison with the Licensee's Analysis Results

➤ Comparison of Cs-137 Release Quantity (Licensee vs MPAS)

■ Comparison of corresponding STCs by Containment Damage State (Licensee vs MPAS)

Containment Damage State	Licensee		MPAS	
	STC	Cs-137 Release Quantities (TBq)	STC	Cs-137 Release Quantities (TBq)
NOCF	10	~1.0	2	~10.0
ECF	15	~10,000.0	4	~100,000.0
LCF	20	~100.0	9	~10,000.0
BMT	11	~0.01	11	~10.0
CFBRB	7	~10,000.0	12	~10,000.0
NOTISO	6	~10,000.0	14	~100,000.0
BYPASS	3	~100,000.0	16	~100,000.0

■ NOCF and BMT < 100 TBq in both analyses

■ MPAS results generally higher than licensee results

3

Conclusion and Further Studies

3 Conclusion and Further Studies

Wrap up

- Selection of Representative Accident Sequences by Containment Damage State (MPAS Level 2 PSA)
 - Selection of sequences with significant radiological impact and high frequency
 - Review to ensure inclusion of key severe accident phenomena
 - Definition of containment failure conditions for each representative sequence

- Source Term Analysis Using MELCOR
 - Simulation of accident progression for representative sequences by containment damage state
 - Consideration of initiating event conditions, availability of safety-related systems, containment failure conditions, and release pathways to the environment

- Calculation of Cs-137 Release Quantity and Frequency of Releases Exceeding 100 TBq
 - Calculation of Cs-137 release quantity using formulation
 - Cs-137 release quantities exceed 100 TBq for all damage states except NOCF and BMT

3 Conclusion and Further Studies

Comparison Results with the Licensee's PSA

- Consistency between independent analyses supports the reliability of Source Term Analysis
 - Different analysis codes were used:
 - Licensee: MAAP
 - MPAS model: MELCOR
 - Containment damage states exceeding 100 TBq of Cs-137 release are identical in both analyses

- Differences in Cs-137 release quantity are observed for the same Containment Damage States
 - MPAS-based results are generally higher than the licensee's results
 - **LCF**: MPAS (MELCOR) $\approx 100\times$ higher than licensee (MAAP)
 - **BMT**: MPAS (MELCOR) $\approx 1,000\times$ higher than licensee (MAAP)
 - Differences are attributed to the modeling approach for source term release through containment design leakage

Further Studies

➤ Cs-137 release frequency exceeding 100 TBq ($\sim 2.5E-06/\text{yr}$) exceeds the regulatory limit

■ Conservative TLOCCW initiating event frequency in Level 1 PSA

■ Fault Tree-based calculation

- Plant configuration during power operation not considered
 - Fail to run modes applied to standby equipment, with a 1-year mission time
 - 4/4 Common Cause Failure (CCF) assumed for ESW pumps
- Approximately 5 times higher than the licensee's initiating event frequency

■ Majority of TLOCCW sequences classified as late containment failure (LCF)

- Driven by failure of containment spray and heat removal

■ Conservative Source Term Analysis by Containment Damage State

■ Most conservative sequence selected for each containment damage state

- Some STCs within the same damage state may result in Cs-137 release below 100 TBq

■ STC-level Source Term Analysis

- Potential reduction of the estimated Cs-137 release frequency exceeding 100 TBq
- Input Development for MPAS Level 3 PSA

➤ Further Studies

■ Re-evaluation of TLOCCW initiating event frequency

■ Source Term Analysis for representative accident sequences at the STC level



Q&A

ABOUT



주|미래와도전
FNC Technology Co., Ltd.

📍 **본사**

16954 경기도 용인시 기흥구 흥덕1로 13,
32층
(영덕동, 흥덕아이티밸리 타워동)
+82-31-8065-5114

📍 **대전지사**

대전광역시 유성구 대덕대로 593, 10층 1004-1호
(도룡동, 대덕테크비즈센터)
+82-42-867-5114

📍 **미래에너지기술연구소**

경기도 용인시 기흥구 탑실로 46,
미래에너지기술연구소
+82-31-8005-5618

설비개발연구센터

경기도 용인시 기흥구 탑실로 46,
미래에너지기술연구소
+82-31-8065-5114

📍 **UAE 아부다비지사**

Office 904, Capital Tower, Al Rawhah,
PO Box 95133, Abu Dhabi, UAE
+971-2-643-5144

📍 **미국 메릴랜드지사**

11140 Rockville Pike, Suite 380A,
Rockville, MD 20852 USA
+1-202-577-5537



THANK YOU



FNC TECHNOLOGY CO., LTD.

