

Fragility Assessment of Piping System in Ulchin 56 NPP based on JNES Results

Min Kyu Kim^{a*}, In-Kil Choi^a

^a Korea Atomic Energy Research Institute, 1045 Daedeok-daero, Yuseong, Daejeon, 305-353

*Corresponding author: minkyu@kaeri.re.kr

1. Introduction

A Piping system is one of the most important systems in NPP, because a piping system carries coolant of NPP system. Failure of piping system reveals LOCA (loss of coolant accident) which can cause core damage. LOCA divide as large, medium and small LOCA according to a size of piping system. Even though LOCA is one of the most important accidents in NPP, LOCA is only considered in the case of internal event in Korea. But JNES (Japan Nuclear Energy Safety Organization) already performed a fragility analysis about piping systems in PWR and BWR system in Japan. And also Japan considered a failure of piping system in the case of seismic event. In this study, fragility results of Japanese NPP were investigated and fragility of piping system in Korea was evaluated by applying to Japanese method.

2. Seismic Fragility Assessment of Piping System in Japanese NPP

JNES already performed seismic fragility analysis for all kinds of NPP in Japan. In the case of 2 loop PWR system, 13 piping systems were selected for seismic fragility evaluation. Table 1 shows target piping system list of Japanese 2-loop PWR system. JNES already evaluated about limit capacity of each piping system. As shown in Table 1, limit accelerations of piping system are different between piping and support. Limit acceleration of piping system is much higher than that of support of piping system. As a result, it can be notice that failure of piping system is governed by seismic capacity of support.[JNES, 2006]

Table 1. Piping systems for fragility evaluation

| | Piping System | Diameter (in) | Natural Frequency | Limit Acc. | |
|----|---------------------------------------|---------------|-------------------|------------|---------|
| | | | | Piping | Support |
| 1 | Pressurizer Surge | 10 | 12 | 56 | 13 |
| 2 | Pressurizer Spray | 3 | 11 | 71 | 17 |
| 3 | Pressurizer Release | 3 | 15 | 28 | 9 |
| 4 | Pressurizer Safety Valve | 4 | 50 | 41 | 36 |
| 5 | Residual heat removal(CV) | 8 | 13 | 32 | 13 |
| 6 | Residual heat removal (outside of CV) | 6 | 20 | 38 | 7.9 |
| 7 | Safety injection(CV) | 8 | 13 | 41 | 13 |
| 8 | Spray Link | 10 | 14 | 77 | 29 |
| 9 | Vertical (CV) | 6 | 12 | 125 | 40 |
| 10 | Main steam(CV) | 30 | 16 | 33 | 6.8 |
| 11 | Main steam(outside of CV) | 28 | 12 | 39 | 14 |
| 12 | Main feed water(CV) | 16 | 16 | 42 | 6.8 |
| 13 | Main feed water(outside of CV) | 16 | 11 | 58 | 19 |

JNES developed a failure probability of failure for piping system of 2-loop PWR in Japan as shown in Table 2. As shown Table 2, failure probability of piping system was determined as each peak acceleration level. So we can

determine a failure probability of piping system at each acceleration level. But if the results shown in Table 2 apply to Korean NPP, the results should be transformed as median probability of failure and uncertainty value. The failure probabilities are transformed as median value and uncertainty value as shown in Table 3. In Table 3, median failure probabilities are shown in 'gal' and 'g'.

Table 2. Failure probability of piping system in 2-loop PWR in Japan

| | failure probability (unit:gal) | | | | | | |
|----|--------------------------------|--------|--------|--------|--------|--------|--------|
| | 300 | 450 | 600 | 750 | 900 | 1100 | 1300 |
| 1 | 8.E-13 | 9.E-10 | 8.E-08 | 1.E-06 | 1.E-05 | 9.E-05 | 5.E-04 |
| 2 | 4.E-05 | 1.E-03 | 7.E-03 | 2.E-02 | 4.E-02 | 9.E-02 | 2.E-01 |
| 3 | 2.E-07 | 3.E-05 | 1.E-03 | 6.E-03 | 2.E-02 | 6.E-02 | 2.E-01 |
| 4 | 3.E-34 | 1.E-30 | 1.E-25 | 7.E-22 | 9.E-20 | 1.E-17 | 8.E-16 |
| 5 | 2.E-07 | 2.E-05 | 4.E-04 | 2.E-03 | 6.E-03 | 2.E-02 | 5.E-02 |
| 6 | 2.E-07 | 2.E-05 | 9.E-04 | 1.E-02 | 4.E-02 | 1.E-01 | 2.E-01 |
| 7 | 1.E-06 | 7.E-05 | 1.E-03 | 5.E-03 | 1.E-02 | 4.E-02 | 7.E-02 |
| 8 | 9.E-19 | 2.E-14 | 4.E-12 | 3.E-10 | 3.E-09 | 8.E-08 | 1.E-06 |
| 9 | 2.E-35 | 9.E-29 | 6.E-25 | 2.E-21 | 4.E-19 | 8.E-17 | 7.E-15 |
| 10 | 6.E-04 | 2.E-02 | 1.E-01 | 2.E-01 | 4.E-01 | 6.E-01 | 8.E-01 |
| 11 | 4.E-08 | 3.E-05 | 1.E-03 | 1.E-02 | 3.E-02 | 6.E-02 | 9.E-02 |
| 12 | 6.E-04 | 2.E-02 | 1.E-01 | 2.E-01 | 4.E-01 | 6.E-01 | 8.E-01 |
| 13 | 2.E-12 | 3.E-08 | 3.E-05 | 9.E-04 | 3.E-03 | 9.E-03 | 2.E-02 |

Table 3. Failure probability of piping system in Japan

| | median(gal) | beta | median(g) |
|----|-------------|-------|-----------|
| 1 | 4.36E+03 | 0.368 | 4.45E+00 |
| 2 | 1.82E+03 | 0.390 | 1.85E+00 |
| 3 | 1.61E+03 | 0.250 | 1.64E+00 |
| 4 | 2.13E+04 | 0.351 | 2.18E+01 |
| 5 | 2.58E+03 | 0.417 | 2.64E+00 |
| 6 | 1.81E+03 | 0.389 | 1.84E+00 |
| 7 | 2.71E+03 | 0.501 | 2.77E+00 |
| 8 | 6.64E+03 | 0.343 | 6.77E+00 |
| 9 | 1.46E+04 | 0.314 | 1.49E+01 |
| 10 | 9.90E+02 | 0.352 | 1.01E+00 |
| 11 | 2.99E+03 | 0.627 | 3.05E+00 |
| 12 | 9.90E+02 | 0.352 | 1.01E+00 |
| 13 | 3.86E+03 | 0.530 | 3.93E+00 |

3. Seismic Fragility Evaluation for Piping System in Ulchin 56 NPP

For the evaluation of fragility of piping system at Ulchin 56 NPP, it assumed that piping system of Japan and Korea are same. For the assessment of response of piping system in Ulchin 56 NPP, FRS of containment and PAB were used. One

of FRS is shown in Figure 1. A seismic fragility was determined by using equation (1) and (2)

$$A_C = \frac{F_C}{F_S} \times A_S \quad (1)$$

$$HCLPF = A_C \cdot e^{-1.65(\beta_r + \beta_u)} \quad (2)$$

where, A_C is a critical acceleration, A_S is an acceleration response of natural frequency of piping system, F_C is critical stress, F_S is a response caused by seismic load, HCLPF is a high confidential and low probability of failure and β_r and β_u are a uncertainty value.




Figure 1. Example of Ulchin 56 NPP FRS (142' containment) [KEPCO, 1997]

Median failure probability and HCLPF are summarized as Table 4 to Table 7 according to the location of containment and PAB. As shown in Table 4 to 7, fragility values of some piping system in Ulchin NPP are lower than that of JNES results. As shown in Table 4 to 7, the failure probability of piping system in Ulchin 56 NPP is not enough for compare of Japanese NPP. Although Japanese seismic design level is much higher than that of Korea NPP, fragility of some piping system might be not sufficient so detail analysis should be needed and failure of piping system should be considered in seismic PSA in Korea.

Table 4. Median probability of failure of piping system in Ulchin 56 NPP (in the containment vessel)

| | Median | Median according to FRS of CV | | | | | | | | | |
|---------------------------------------|--------|-------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | | JNES | 100NS | 100EW | 111NS | 111EW | 122NS | 122EW | 132NS | 132EW | 142NS |
| Piping system | 4.45 | 3.20 | 2.67 | 2.53 | 2.00 | 2.00 | 1.66 | 1.85 | 1.50 | 1.71 | 1.41 |
| Pressurizer Surge | 1.85 | 2.75 | 2.44 | 2.32 | 1.83 | 1.83 | 1.52 | 1.69 | 1.38 | 1.57 | 1.29 |
| Pressurizer Spray | 1.64 | 4.00 | 3.33 | 3.16 | 2.50 | 2.50 | 2.07 | 2.31 | 1.88 | 2.14 | 1.76 |
| Pressurizer Release | 21.76 | 40.00 | 38.46 | 35.71 | 33.33 | 31.25 | 28.57 | 28.57 | 26.32 | 26.32 | 23.81 |
| Residual heat removal(CV) | 2.64 | 3.47 | 2.89 | 2.74 | 2.17 | 2.17 | 1.79 | 2.00 | 1.63 | 1.86 | 1.53 |
| Residual heat removal (outside of CV) | 1.84 | | | | | | | | | | |
| Safety injection(CV) | 2.77 | 3.47 | 2.89 | 2.74 | 2.17 | 2.17 | 1.79 | 2.00 | 1.63 | 1.86 | 1.53 |
| Spray Link | 6.77 | 3.73 | 3.11 | 2.95 | 2.33 | 2.33 | 1.93 | 2.15 | 1.75 | 2.00 | 1.65 |
| Vertical (CV) | 14.87 | 3.20 | 2.67 | 2.53 | 2.00 | 2.00 | 1.66 | 1.85 | 1.50 | 1.71 | 1.41 |
| Main steam(CV) | 1.01 | 7.11 | 5.82 | 5.82 | 4.27 | 4.57 | 3.76 | 3.56 | 3.20 | 3.20 | 2.67 |
| Main steam(outside of CV) | 3.05 | | | | | | | | | | |
| Main feed water(CV) | 1.01 | 7.11 | 5.82 | 5.82 | 4.27 | 4.57 | 3.76 | 3.56 | 3.20 | 3.20 | 2.67 |
| Main feed water(outside of CV) | 3.93 | | | | | | | | | | |

Table 5. HCLPF of piping system in Ulchin 56 NPP (in the containment vessel)

| | HCLPF | HCLPF according to FRS of CV | | | | | | | | | |
|---------------------------------------|--------|------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| | | JNES | 100NS | 100EW | 111NS | 111EW | 122NS | 122EW | 132NS | 132EW | 142NS |
| Piping system | 1.886 | 1.36 | 1.13 | 1.07 | 0.85 | 0.85 | 0.70 | 0.78 | 0.64 | 0.73 | 0.60 |
| Pressurizer Surge | 0.621 | 0.92 | 0.82 | 0.78 | 0.61 | 0.61 | 0.51 | 0.57 | 0.46 | 0.53 | 0.43 |
| Pressurizer Spray | 0.695 | 1.70 | 1.41 | 1.34 | 1.06 | 1.06 | 0.88 | 0.98 | 0.79 | 0.91 | 0.75 |
| Pressurizer Safety Valve | 10.782 | 19.82 | 19.06 | 17.70 | 16.52 | 15.49 | 14.16 | 14.16 | 13.04 | 13.04 | 11.80 |
| Residual heat removal(CV) | 1.035 | 1.36 | 1.13 | 1.07 | 0.85 | 0.85 | 0.70 | 0.79 | 0.64 | 0.73 | 0.60 |
| Residual heat removal (outside of CV) | 0.690 | | | | | | | | | | |
| Safety injection(CV) | 1.036 | 1.30 | 1.08 | 1.03 | 0.81 | 0.81 | 0.67 | 0.75 | 0.61 | 0.70 | 0.57 |
| Spray Link | 2.958 | 1.63 | 1.36 | 1.29 | 1.02 | 1.02 | 0.84 | 0.94 | 0.76 | 0.87 | 0.72 |
| Vertical (CV) | 7.368 | 1.59 | 1.32 | 1.25 | 0.99 | 0.99 | 0.82 | 0.91 | 0.74 | 0.85 | 0.70 |
| Main steam(CV) | 0.441 | 3.11 | 2.54 | 2.54 | 1.86 | 2.00 | 1.64 | 1.55 | 1.40 | 1.40 | 1.17 |
| Main steam(outside of CV) | 1.123 | | | | | | | | | | |
| Main feed water(CV) | 0.441 | 3.11 | 2.54 | 2.54 | 1.86 | 2.00 | 1.64 | 1.55 | 1.40 | 1.40 | 1.17 |
| Main feed water(outside of CV) | 1.428 | | | | | | | | | | |

Table 6. Median probability of failure of piping system in Ulchin 56 NPP (in the PAB)

| | JNES | Median | | | | | | | |
|---------------------------------------|-------|-----------|-------|-------|-------|--------|--------|--------|--------|
| | | U56 (PAB) | | | | | | | |
| | | 100EW | 100NS | 125EW | 125NS | 144 EW | 144 NS | 165 EW | 165 NS |
| Piping system | 1.842 | 2.110 | 1.892 | 1.704 | 1.820 | 1.816 | 1.775 | 1.362 | 1.432 |
| Residual heat removal (outside of CV) | 3.046 | 2.667 | 3.457 | 1.735 | 2.074 | 1.346 | 1.481 | 1.111 | 1.148 |
| Main steam(outside of CV) | 3.934 | 3.423 | 3.762 | 2.354 | 2.123 | 1.827 | 1.526 | 1.434 | 1.176 |
| Main feed water(outside of CV) | | | | | | | | | |

Table 7. HCLPF of piping system in Ulchin 56 NPP (in the PAB)

| | JNES | HCLPF | | | | | | | |
|---------------------------------------|-------|-----------|-------|-------|-------|--------|--------|--------|--------|
| | | U56 (PAB) | | | | | | | |
| | | 100EW | 100NS | 125EW | 125NS | 144 EW | 144 NS | 165 EW | 165 NS |
| Piping system | 0.690 | 0.791 | 0.709 | 0.639 | 0.682 | 0.680 | 0.665 | 0.510 | 0.537 |
| Residual heat removal (outside of CV) | 1.123 | 0.984 | 1.275 | 0.640 | 0.765 | 0.496 | 0.546 | 0.410 | 0.423 |
| Main steam(outside of CV) | 1.428 | 1.243 | 1.366 | 0.855 | 0.771 | 0.663 | 0.554 | 0.521 | 0.427 |
| Main feed water(outside of CV) | | | | | | | | | |

5. Conclusions

In this study, fragility assessment results for piping system in Japan NPP were determined and apply to Korean NPP. Seismic capacity of some piping system in Korea is lower than that of Japan NPP. Because a seismic design level of Korea is much lower than that of Japan, safety of NPP might not be a big problem. But seismic fragility evaluation for piping system should be needed and failure of piping system should be considered in seismic PSA in Korea.

ACKNOWLEDGEMENT

This work was supported by Nuclear Research & Development Program of the National Research Foundation (NRF) grant funded by the Korean government (MEST).

REFERENCES

- [1] 地震に係る確率的な安全評価手法の整備に関する報告書 = 機器フラジリティ評価 (PWR プラント) = 独立行政法人原子力安全基盤機構 JNES/SAE06-024, 06 解部報-0024
- [2] Korea Power Engineering Company, INC., Seismic Analysis of Containment Building, Ulchin Nuclear Power Plant Units 5&6, 1997